



December 8, 2023

Vermont Public Utilities Commission
112 State Street
Montpelier, VT 05620-2701

RE: GMG Farms Net Metering Application, Response to GMP Objections

To Whom it May Concern:

This letter is in response to the objections from Green Mountain Power (GMP) dated November 15, 2023 and is written on behalf of the applicant. Please note that I am no longer employed at DC Energy Innovations, Inc., the installer that began the net metering application process. I am now at Energy Efficient Investments, Inc. (EEI) and continue to serve as the permitting advisor and construction lead for the project.

In response to GMP's first objection, the Solark 15K-2P inverter will be the solar inverter interacting with the utility. The two Solis inverters will only provide AC input to the Solark inverter. The Solark 15K-2P is certified to UL 1741SB, CA Rule 21 and HECO Rule 14H. This appears to meet the inverter source requirements of ISO-NE. We have uploaded to this case the inverter specification sheet and related certification documents.

In response to GMP's second objection, we did meet with a representative of GMP on site to determine more accurately the upgrades needed. The final cost determined for the transformer upgrade is acceptable to the applicant and the applicant understands this to be at the cost of the project.

We appreciate your consideration of this letter. If you have any questions or need any more information, please do not hesitate to contact me.

Sincerely,


Ben Gordesky

Solar Project Developer/Project Manager