

**STATE OF VERMONT
PUBLIC UTILITY COMMISSION**

Petition of GMP MicroGrid-Milton LLC for)
a Certificate of Public Good, pursuant to 30)
V.S.A. § 248, authorizing the installation and)
operation of up to a 4.99 MW solar electric)
generation facility and 2 MW battery storage)
facility to be located off of Mears Road in)
Milton, Vermont and to be known as the)
“GMP MicroGrid-Milton Project”)

Case No. 17-5003-PET

SECOND SUPPLEMENTAL PREFILED DIRECT TESTIMONY OF KIRK SHIELDS

April 20, 2018

Summary: Mr. Shields’ supplemental testimony provides additional Project information based on feedback received from the Department of Public Service.

1 **Q1. Please state your name, occupation and business address.**

2 A1. My name is Kirk Shields and I am Director of Development and Risk Management for
3 Green Mountain Power Corporation (“GMP”). My business address is 2152 Post Road,
4 Rutland, VT 05701.

5

6 **Q2. Have you previously submitted testimony in this proceeding?**

7 A2. Yes, I submitted prefiled direct testimony on behalf of Petitioner GMP MicroGrid-Milton
8 LLC (“MGM”) that was included with the petition for the Milton GMP MicroGrid-Milton
9 Project (“Project”) on November 22, 2017. I also submitted supplemental testimony on
10 March 23, 2018.

11

12 **Q3. What is the purpose of your supplemental testimony?**

13 A3. The purpose of my testimony is to provide additional supporting information about the
14 Project based on feedback received from the Department of Public Service (“DPS”). Since
15 the Petition was filed and over the course of discovery, GMP has had several discussions
16 with the DPS about the proposed Project. DPS staff have provided valuable and critical
17 feedback about where my original testimony could be supplemented with more information
18 in order to provide the best understanding of the Project. In response, GMP is now
19 providing information about the following areas of the Project: a) Project location in relation
20 to distribution grid attributes; b) alternatives for satisfying the Need criterion (section
21 248(b)(2)); c) Renewable Energy Standard (RES) compliance and potential for Tier II supply
22 excess; and d) final updates to the Project’s cost benefit analysis.

23

1 **Q4. The Department has requested supplemental information concerning whether the**
2 **location of the Project will provide discrete benefits GMP's distribution grid. Please**
3 **respond.**

4 A4. GMP collects operational data about each of its distribution circuits. This data is used to
5 monitor the health of the distribution system and for anticipating future configurations of
6 the system as the area being served by the distribution circuit changes or grows. The Project
7 will interconnect to the West Milton substation via the WM-G91 circuit. The West Milton
8 substation also feeds the WM-G92 circuit to the south. The attributes of both the WM-G91
9 and the WM-G92 circuits are relevant here since the Project will positively affect both
10 circuits in ways I will describe further.

11 First, the WM-G91 and WM-G92 circuit peak loads are highly coincident with the
12 time of GMP's overall system peak load hours. With such a high coincidence, load
13 reduction measures taken during the overall GMP system peak hour also have a very high
14 probability of reducing the local system peak load on the WM-G91 and WM-G92 circuits.
15 Additionally, the WM-G92 circuit contains a higher saturation of commercial loads, relative
16 to the WM-G91 circuit, and is experiencing some load growth. When the Project battery
17 discharges energy during peak load times, less energy will need to be pulled through the
18 substation transformer to serve local loads, thereby helping to unload the substation
19 transformer during peaks. Thus, due to this coincident nature of local and system peaks,
20 unloading the substation transformer will extend its life as growth continues to occur and
21 ultimately delay the need for replacement. The West Milton substation currently peaks at
22 about 8 MVA, with a top rating of 10.5 MVA. There are currently three new customers who
23 have sought ability-to-serve determinations from GMP for a total new load of about 990

1 kVA on the WM-G92 circuit. While we are not yet at the operating limit of the West Milton
2 substation transformer, we do anticipate some continued growth on the WM-G92 circuit
3 which will eventually lead to the need to explore options for accommodating that growth.
4 This battery system will have the ability to reduce the flows through the transformer by
5 about 2MWs during peak times, extending the transformer's useful life.

6 Second, the WM-G91 is served by a radial transmission line (Line 125, Breaker B17)
7 and has weak feeder backup to the adjacent substation. This means that the feeder backup
8 scheme can only be used under a limited set of load conditions to assure voltage and line
9 loading remain within reasonable windows while carrying one circuit from the other. The
10 radial transmission line (Line 125) is over 2 miles long and feeds the West Milton substation
11 from the Milton substation. Because this is the only source to the West Milton substation, if
12 the radial transmission line goes out of service, all loads served by the West Milton
13 substation go out as well. Historically, it has been challenging to use the feeder tie, but with
14 the battery tied into the circuit, feeder backup can be used much more frequently, improving
15 reliability in the area. This is because the battery storage can provide voltage stability as well
16 as loading stability (acting as a load or a source as needed) during a time of feeder backup,
17 which would expand the window of time that feeder backup could be performed reliably.
18 The combination of the proposed solar and 2MW battery storage is expected to be capable
19 of islanding the entire 2MW peak load on the WM-G91 circuit, so as designed the Project
20 size and the feeder size match up very well. As previously alluded to, GMP concluded
21 vendor selection for GMP's battery project in Pantou by engaging with system protection
22 partner Schweitzer Engineering Laboratories (SEL) to provide the detailed documentation
23 and specifications to maintain system protection during islanding mode. We will be testing

1 this design on our Panton Energy storage project and then repeating it for the Milton solar
2 storage project.

3 During the October 2017 statewide wind event, all customers on the WM-G91
4 circuit experienced an average of 37 hours of power interruption, with a few customers
5 experiencing over 4 days of no power. Additionally, following that event GMP discovered a
6 broken insulator on one of the poles on the L125 radial transmission line. This finding
7 required an emergency outage be taken on the transmission line in order to make the repair,
8 which resulted in a four-hour power interruption to all the customers on the West Milton
9 substation. With the solar storage project in place and the ability to island, we would have
10 avoided the outage to at least the customers on the WM-G91 circuit or a total of about 1,800
11 customers. Table 1 below shows the Customer Average Interruption Duration Index
12 (CAIDI) and System Average Interruption Frequency Index (SAIFI) statistics for the WM-
13 G91 and WM-G92 circuits where the impact of the 2017 storm is evident:

14
15

TABLE 1			
WM-G91		CAIDI (avg. outage hours)	SAIFI (avg. # outages)
	2014	1.79	1.51
	2015	2.98	.96
	2016	1.07	1.79
	2017	11.1	2.12
WM-G92			
	2014	1.18	0.54
	2015	1.74	0.78
	2016	1.19	1.26
	2017	9.50	2.70

16
17
18
19
20
21


22 The islanding capability would not necessarily eliminate all of these customer
23 impacts, but we are confident that it would have improved our system performance to many

1 of the customers served by the West Milton substation. The customer impact of islanding
2 capability depends on the actual location of a system fault relative to the location of the solar
3 storage facility since electricity must remain physically able to flow between the solar storage
4 facility and an islanded customer.

5 Third, site location for projects of this size matters for ease and cost efficiency of
6 interconnection as well. A contributing factor for selecting this site was the large
7 distribution conductor infrastructure already available at roadside, so no reconductoring or
8 existing pole upgrades were expected to be required for interconnection. Wire size and
9 ampacity is an important consideration since locations with small wire are most likely to
10 require extensive reconductoring to make interconnection possible. Ampacity represents the
11 amount of electric current (measured in amps) that a conductor can carry before
12 experiencing deterioration. Referring to Figure 1 below, circuit ampacity over GMP's entire
13 system is shown with varying degrees of wire size and ampacity shown. Much of GMP's
14 system consists of wire that is rated below 250 amps, with fewer places on the map
15 indicating ampacity of 600 amps. The proposed Project location is circled on the map as a
16 blue highlighted section with high ampacity. The system impact study confirmed that no
17 reconductoring is required for interconnecting the Project.

18

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17



18
19
20
21
22

Similarly, a Project's interconnection to the distribution system is also dependent on the influence of voltage flicker that the new asset will have on the system. Figure 2 shows a similar map of GMP's system, graded for probability of voltage flicker. The Project location is connected to a part of the system that has a low probability of voltage flicker, as confirmed by the system impact study.

1 The takeaway from both of these maps is that the Project location is good from both
2 grid and interconnection capability perspectives.

3
4 **Q5. The Department has requested supplemental information concerning the**
5 **alternatives to the Project that GMP identified and evaluated to deliver comparable**
6 **benefits (i.e., load shaving, peak reduction, associated cost savings) to customers.**
7 **Please respond.**

8 A5. GMP currently employs various load management tools for pursuing peak shaving and load
9 reduction benefits for customers, and has the ability to reduce demand of between 19 MW
10 and 68 MW depending on response and season. None of the current load management
11 methods, including the intended uses of the proposed Project, are mutually exclusive,
12 meaning that GMP pursues multiple strategies simultaneously in order to reduce power costs
13 for customers. Load management strategies currently being deployed by GMP include:

- 14 • Curtailable Load Rider (2 MW- 5 MW summer; 45 MW winter)
- 15 • Pilot Demand Response Program (5 MW-10 MW)
- 16 • Critical Peak Rider (2 MW)
- 17 • Water Heater program (6 MW-7 MW)
- 18 • Sonnen residential batteries (86 kW)
- 19 • Tesla Powerwall (ramping up to 1.5 MW)
- 20 • Sensibo Heat Pump controls (80 kW)
- 21 • Aquanta Water Heater controls (75 kW)
- 22 • IceBear load shifting (21 kW)
- 23 • Stafford Hill Battery (2 MW)
- 24 • EV Car Chargers (340 kW)

1 GMP's strategy for deploying demand and load management resources across the
2 system hinges on a continuously evolving mix of resources depending on customer needs,
3 with various costs, benefits, sizes, duration, customer requirements and technical feasibility.
4 We believe the best approach is a portfolio approach, distributed mix of resources that
5 includes small-scale, behind-the-meter and distribution-connected systems such as this
6 project.

7 With that in mind, GMP is continually seeking out new opportunities to achieve cost
8 beneficial and flexible load control for customers. Our initial development of flexible load
9 resources mainly focused on the residential behind-the-meter space, however we have begun
10 working with different parties and technologies for flexible, commercial-scale controls and
11 load flexibility behind the typical tariff rate and rate rider approaches. We are currently
12 partnering with third parties to explore commercial scale load shifting through building
13 management systems and 'phase change material' such as ice and chilled water storage. The
14 notion being that larger commercial customer locations with cooling loads can produce
15 chilled water or ice during off-peak, overnight hours and then utilize this ice or chilled water
16 to cool interior spaces during the day, moving load from day to night. Conversely, if an area
17 were heavily saturated in solar it may make sense to make ice during peak solar periods and
18 then utilize the ice for space cooling during the evening peaks in place of electricity-driven
19 A/C compressors. We are engaged in the discussion around savings sharing ideas with the
20 partner to make the concept work.

21 Notwithstanding everything above, there are additional value streams that this solar-
22 storage facility will provide that are not easily obtained from other flexible resources
23 described above including: frequency regulation, islanding, system power quality/voltage

1 management. Frequency regulation is a part of the financial model for this project,
2 providing revenues back to customers in exchange for providing ISO New England with a
3 fast-response resource that is larger than 1MW in size. Islanding requires an actual power
4 source that can re-energize the grid; this cannot be obtained solely from flexible loads or
5 load control. Lastly, the distribution system power quality component relies on the power
6 electronics that are coupled with the solar and battery storage systems to produce reactive
7 power and voltage smoothing when helpful to the local distribution system. Flexible loads
8 can play a small part in system quality but cannot provide the reactive power needed to shift
9 the voltage substantially when needed. For these reasons, GMP concludes that a battery
10 storage system is the appropriate load management solution at this location for the intended
11 use cases.

12
13 **Q6. The Department has requested supplemental information concerning GMP's**
14 **compliance with RES requirements and the potential that it will have excess Tier II**
15 **supply. Please respond.**

16 A6. Tier II RECs are eligible to meet Tier III obligations and so are valuable hedges against the
17 Tier III Alternative Compliance Payment (ACP) of \$60/MWh. I start off with this
18 statement because the explanation of the planning logic is rather involved.


19 To explain the thinking behind this hedge strategy, GMP acknowledges that its
20 analysis indicates that it may have an excess supply of Tier II RECs, relative to its obligations
21 under Vermont's RES program for at least several years into the future. Beyond the Tier II
22 obligation, GMP also has an additional Tier III obligation for helping customers to move
23 from fossil fuel to efficient electrification.

1 GMP exceeded its Tier III project targets in 2017. We expect to exceed Tier III
2 targets again in 2018 based on our current pace of customer participation in our portfolio of
3 programs. However, despite the initial success, the growth of the Tier III annual
4 requirement is steep over the fifteen-year period of the statute. What began in 2017 as a
5 target of 2% of retail MWh sales grows to 12% by 2032. We support these targets and also
6 support the Tier III provision of RES fully, but as the annual targets steeply increase and the
7 easier customer projects are completed in the early years, we see a need to hedge our future
8 Tier III requirements with Tier II excess in order to manage ACP cost risk.

9 Figures 3 and 4 below illustrate two possible scenarios of future Tier III outcomes.
10 Figure 3 illustrates a Low Tier III Case where initial years' requirements are met but
11 subsequent years' Tier III projects fall well short of requirements. In that case, excess Tier
12 II RECs are sufficient to satisfy Tier III compliance, except in the last 2 years where
13 requirements are not met even after using all available excess Tier II RECs. Figure 4
14 illustrates a High Tier III Case where Tier III projects are sufficient to meet requirements for
15 at least the first half of the program period, then require Tier II RECs to help meet
16 requirements through the end of the program period.

1

Figure 3 – Low Tier III Case




2

3

4

Figure 4 – High Tier III Case



5

1 At this early stage in the program cycle, while it is difficult to confidently predict
2 which of the possible outcomes is most likely to prevail, a \$60/MWh ACP in the Low Case
3 is the outcome that GMP believes is appropriate to hedge against.

4
5 **Q7. Please explain why the financial model has been updated a number of times, and**
6 **provide the final updates.**

7 A7. As with any project, we are continually looking for ways to reduce the cost of deployment
8 which ultimately leads to updates in the financial model. GMP has made one last set of
9 updates to the financial model, and can now confirm that the model is stable and locked
10 down in final form.

11 In summary, the final updated model indicates that the battery storage value to be
12 realized by customers will increase to \$285/kW-year, versus the value of \$233/kW-year
13 reported in my original testimony. The estimated solar all-in levelized costs to customers is
14 reduced slightly to \$0.081/kWh versus the \$0.083/kWh stated in my original testimony.

15 Andrew Quint provides additional detail about the updates to the final model in his
16 supplemental testimony.

17
18 **Q8. Since the original Petition was filed, a new module import tariff was levied. Will that**
19 **have an effect on Project costs? If so, what are those effects?**

20 A8. The International Trade Commission (“Trade Commission”) received a complaint that
21 cheap solar module imports were hurting domestic solar module manufacturers who
22 produce solar modules at higher costs. The Trade Commission ruled in favor of the
23 complainants and President Trump authorized a 30% import tariff be placed on certain

1 imported solar modules (with the rate declining over a four-year period to 15%).
2 Fortunately, GMP's contractor has insulated GMP from the financial effects of that new
3 import tariff through bulk module purchases, so there is no resulting cost impact to the
4 Project.

5

6 **Q9. Does this conclude your supplemental testimony?**

7 A9. Yes, it does.