

Instructions for Participating in the Review of the Attached Net-Metering Application

Any person may file a public comment addressing whether the application should be approved. Public comments may be filed via the Commission's online document management system, known as ePUC, which you can access on the Commission's website at puc.vermont.gov, or mailed to the Commission at 112 State Street, 4th Floor, Montpelier, VT 05620-2701.

If you wish to participate in the review of a CPG application as a party, which is a prerequisite filing an appeal of a final Commission decision, you must obtain party status from the Commission. The following persons may obtain party status by filing a notice of intervention form with the Commission by the deadline that is stated on the first page of the application:

- adjoining landowners,
- the municipal legislative bodies and the municipal and regional planning commissions where the net-metering system will be located,
- under certain circumstances, the municipal legislative bodies and the municipal and regional planning commissions of an adjacent municipality or region (see Commission Rule 5.116(B) for more information),
- the Vermont Agency of Agriculture Food and Markets,
- the Vermont Division for Historic Preservation, and
- the applicant's electric utility service provider.

If a party wishes to offer contrary evidence or to challenge the accuracy of information contained in an application, the party must request a hearing to present such evidence and argument. To request a hearing, a party may use the attached hearing request form. All requests for hearing must be filed by the deadline that is stated on the first page of the application.

Motions to intervene, notices of intervention, and requests for hearing may be filed with the Commission via the Commission's online document management system, known as ePUC, which you can access on the Commission's website at puc.vermont.gov or mailed to the Commission at 112 State Street, 4th Floor, Montpelier, VT 05620-2701. If you use ePUC to make such filings, ePUC will automatically provide notice of and access to your filing to all other parties who are participating in the case electronically. You must mail a copy of your filing to any party who is not participating in the case electronically (parties with an email address listed on the People tab in ePUC are participating electronically). If you mail your filing to the Commission, you must also mail a copy of your filing to all other parties in the case.

For more information about participating in the review of applications for CPGs, see Commission Rule 5.100 on the Commission's website (puc.vermont.gov).

Net-Metering Application Form

Applicant Information	
Applicant Name	Margo Avery Trust
Applicant Mailing Address	2049 Century Park East Suite 1400
Town/City/State	Los Angeles
Zip Code	90067
Daytime Telephone	(310) 315-6242
Email Address	rhimesteam@savco.com
Name of Utility	Green Mountain Power Corporation
Consumption Meter Number	E15064111
Is this a group net-metering system?	No
Is the property owner the same as the net-metering customer/applicant?	Yes
Do you elect to retain or transfer ownership of any environmental attributes associated with the system?	Transfer Ownership
Advance Filing Reference Number	20-1635-AN

System Information	
System Location	297 Tucker Hill
Town/City/State	Norwich
Zip Code	05055
Existing CPG Number (if amendment)	
Description of Proposed Amendment	
Number of Act 250 Land Use Permit applicable to the host parcel (if any)	
Are there one or more existing, approved, or other proposed net-metering systems at this service address?	N
Case Number(s) or CPG Number(s) of Other Systems	

Photovoltaic System Information	
System Capacity (AC nameplate capacity of the inverter(s))	29.4 AC Kilowatts
PV Module Manufacturer	Hanwha QCELL
PV Module Model Number	QPEAK DUO G5 315
Number of Modules	96
Power Rating per Module	315 Watts
Total Array Output (no. of modules x power rating)	30.24 Kilowatts
Inverter Manufacturer	SMA
Inverter Model Number	3 x SB-6.0, 3 x SB-3.8
Physical Location of the Facility's Lockable Disconnect Switch	There will be lockable disconnects at the array, and at the transformer, located on the driveway.
Interconnection Configuration	Behind Consumption Meter
Installation Type	Ground Mount
System Orientation	Fixed
Will the applicant own or lease the generation equipment?	Own
Setback Information	
Distance to the Nearest Residence	1140 ft.
Name of and Distance to Each Adjoining Municipal or State Highway	Burton Woods Rd, 2985 ft. Burton Woods Rd, 1005 ft.
Distance to All Adjoining Property Boundaries that Are Not State or Municipal Highways	Kitchel, 555 ft. Guest, 1500 ft. Morley, 720 ft.
Do the municipal bylaws or ordinances of the municipality where the project will be located contain any screening requirements for ground-mounted solar facilities?	No
Is the proposed project in compliance with the municipality's screening requirements?	
System Installer Information (if different than Applicant information)	
Installer Name	Darren O'Meara, O'Meara Solar
Mailing Address	PO BOX 151
Town/City/State	WEST TOPSHAM, VT
Zip Code	05086
Daytime Telephone	8025222381
Email Address	omearasolar@gmail.com
Owner of Generation Equipment (if different than Applicant)	
Owner Name	
Mailing Address	
Town/City/State	,
Zip Code	
Daytime Telephone	
Email Address	

Environmental Information / Preferred Sites	
System will be sited on, near, or within the following resources	
Type(s) of Preferred Site	Not a Preferred Site Near customer load E15064111, 100% of the project's output is going to the customers load.

Visible and Aesthetic Impact	
Description of the visible and aesthetic impact of the project and why it will not have an undue adverse effect on aesthetics and the scenic and natural beauty of the area. Description of the location of the facility in relation to adjoining properties, including a specific statement about the visibility of the facility from adjoining properties; and, if it is highly visible, what measures the applicant has taken, if any, to minimize the visible impact.	

Certification

The undersigned declares, under the pains and penalties of perjury, that to the best of my knowledge:

- (1) having exercised due diligence and made reasonable inquiry, the information which I have provided on this form and any attachments is true and correct;
- (2) I have complied with the advance notice requirements of Public Utility Commission Rule 5.106(C);
- (3) the project for which this application seeks approval is in compliance with the land conservation measures contained in the applicable Town Plan;
- (4) the project is in compliance with all applicable local, state, and federal requirements and has all other necessary approvals for operation of this type of system;
- (5) any waste generated by the construction of this project will be disposed of at a state-approved disposal facility;
- (6) any construction activities will follow the recommendations of the Low Risk Site Handbook for Erosion Prevention and Sediment Control (available from the Agency of Natural Resources Stormwater Program);
- (7) the system will be installed in compliance with the interconnection, safety, and technological requirements of Vermont Public Utility Commission Rule 5.100;
- (8) this application will not result in more than 500 kW of cumulative net-metering generation being allocated to any customer consistent with Commission Rule 5.129(D) and the definitions of the terms “account” and “customer” contained in Commission Rule 5.103;
- (9) within two business days of a determination that this application is administratively complete, I will mail a copy of this complete application to all parties as required by this form;
- (10) site preparation or construction of the project will not commence until a Certificate of Public Good is issued;
- (11) if I am a system installer, the Applicant has authorized me to submit this registration form on behalf of the Applicant and the Applicant has signed a binding contract for the installation; and
- (12) I have paid the required Department/Commission Application Fee to the Department of Public Service.

Making false or misleading statements on this application is subject to penalties under 30 V.S.A. § 30 and/or amendment or revocation of any approval granted. Such revocation could require you to remove the project and restore the site to its original condition.

Darren O'Meara

Filer Name

08/18/20

Date Filed with the Commission