



**Karly Carrara, Distributed Generation Coordinator**  
**2152 Post Road, Rutland, Vermont 05701 \* 802-770-3224**

October 9, 2020

Judith Whitney, Clerk  
Public Utility Commission  
112 State Street  
Montpelier, VT 05620

**Filed in ePUC**

RE: 20-2276-NM - Application of Margo Avery Trust for a certificate of public good for a 29.4 kW solar net-metered electric power system in Norwich, Vermont (the Project).

Dr. Ms. Whitney,

Green Mountain Power (GMP) engineering review pursuant to Vermont Public Utility Commission Rule 5.106(H) identified that for this project to interconnect safely and reliably the fuses at taglets 72819 and 72808 must be upgraded from a 10K to 12K and from a 15K to 20K respectively. GMP will communicate the costs for these upgrades to the Project.

Additionally, the Project proposes interconnection to a customer owned 15 kVA transformer. GMP strongly suggests the transformer be upgraded to a 37.5 kVA unit but because it is customer owned and will not impact the GMP system, we do not require such an upgrade. Failure to upgrade the transformer could result in elevated voltages at the service location and/or loss of life of the transformer.

GMP has no additional comments regarding this project.

Please let me know if we can be of further assistance.

Sincerely,

*Karly Carrara*

Karly Carrara  
Distributed Generation Coordinator

Cc: DPS/Developer