



Karly Carrara, Distributed Generation Coordinator
2152 Post Road, Rutland, Vermont 05701 * 802-770-3224

October 13, 2020

Judith Whitney, Clerk
Public Utility Commission
112 State Street
Montpelier, VT 05620

Filed in ePUC

RE: 20-2276-NM - Application of Margo Avery Trust for a certificate of public good for a 29.4 kW solar net-metered electric power system in Norwich, Vermont. (the Project).

Dr. Ms. Whitney,

Green Mountain Power (GMP) engineering review pursuant to Vermont Public Utility Commission Rule 5.106 (H) identified that for this project to interconnect safely and reliably the fuses at taglets 72819 and 72808 must be upgraded from a 10k to 12k and from a 15k to 20k respectively.

These costs will be communicated with the Project.

GMP has no additional comments regarding this project.

Please let me know if we can be of further assistance.

Sincerely,

Karly Carrara

Karly Carrara
Distributed Generation Coordinator

Cc: DPS/Developer