

TOWN OF RANDOLPH, VERMONT

Zoning and Planning Office

zoning@randolphvt.org

802.728.5433 x13

To: Norwich Solar Technologies, Inc.
15 Railroad Row
White River Junction, VT 05001
Attn: Martha Staskus

14 December 2021

From: The Town of Randolph
Planning Commission
7 Summer Street, Drawer B
Randolph, VT 05060

Subject: Notice of Discrepancy in the Davis Road Preferred Site Location for a Solar Array

In response to our Notice of Discrepancy (subject as above) the Randolph Planning Commission received your response on 13 Dec 2021 and accepts your guarantee that “prior to installation of the panels, Norwich Technologies will confirm the grade slopes in the area of the solar panels by having a Vermont licensed surveyor set grade stakes for the solar array rows location and document the slopes. The parties have noted specific concern to the terrain on the eastern side of the array, and again, confirmation will be secured before any panels are installed in that location. The array will be arranged so that solar panels within the current limit of disturbance are not installed on slopes greater than 25%. The onsite survey data can be provided to the Town and the Allen/Binders upon request.”


We request that the onsite survey data mentioned above be provided to both the Town of Randolph and the Allen/Binders. We further request to see your final Solar Array plot plan prior to construction.

Thank you for your attention to this matter.

Respectfully

//original signed//

George “Sonny” Holt
Chair
Randolph Planning Commission



8434051_1:12602-00071