

9/29/2025

To: Northland Solar LLC

VEC has changed the delivery point for Northland Solar LLC. After review by a utility designer, it was determined that the interconnection route from the substation could be simplified by locating the delivery point to the Lowell 05-1A distribution line pole JYT 2.

The reason for this change was to reduce the amount of conductor replacement and associated costs required to interconnect the project. This change does not require additional analysis, because it does not significantly alter the length of the interconnection as studied. The system impact results and requirements are unchanged, other than the few spans of conductor that no longer need to be upgraded because they are no longer part of the interconnection path back to the substation.

Regards,
Michael Beaulieu
System Engineer
Vermont Electric Coop

