



General Notes

1. PRELIMINARY DRAWING; NOT FOR CONSTRUCTION. FINAL SITE LOCATION, LAYOUT AND DESIGN SUBJECT TO ENGINEERING DESIGN AND REVIEW.
2. LAYOUT SHOWS GENERAL FOOTPRINT REQUIRED FOR FACILITY. SITE LOCATION AND DETAILED LAYOUT AND CONSTRUCTION DRAWINGS TO BE DEVELOPED LATER.

SYSTEM RATING

4.999 MW, 4 HR

INTERCONNECTING VOLTAGE

12.47 KV

FACILITY POWER AT POI

4.999 MW

FACILITY ENERGY AT POI

23.5 MWH

SITE AREA

7,572 SQFT

INVERTER MANUFACTURER

EPC POWER

BATTERY MANUFACTURER

TRINA

No.	Revision/Issue	Date

LIGHTSHIFT
ENERGY

1201 WILSON BLVD, FL 27
ARLINGTON, VA 22209
571-447-9180

Project Name and Address

Vergennes VT BESS 1
99 Panton Rd
Vergennes, VT
44.163073, -73.262208

Drawing Number
DWG-004-G

Date
11/4/2025

Scale
3/8" = 12'

Sheet

02