

- PROPOSED ANTENNAS & EQUIPMENT ON PROPOSED CONCRETE OR HARVESTORE SILO.

- NEW ANTENNAS: 2 ANTENNAS PER SECTOR, 6 TOTAL.
- NEW MMUs: 1 PER SECTOR, 3 TOTAL.
- NEW RRRHS: 2 RRRHS PER SECTOR, 6 TOTAL.
- NEW 12-PORT OVP DISTRIBUTION BOX, 1 TOTAL.
- NEW POWER TRUNK.
- NEW FIBER TRUNK.

- NEW 12'x20' EQUIPMENT SHELTER.
- NEW (2) EQUIPMENT CABINETS.
- NEW 50KW DIESEL GENERATOR.
- NEW CABLE BRIDGE.
- NEW ELECTRICAL AND TELEPHONE SERVICE.


1. SITE ADDRESS:	189 SOUTH STREET SOUTH HERO, VT 05486
2. COORDINATES:	LAT: 44°-37'-14.89"± (44.620803°±) LONG: 73°-18'-04.76"± (73.301322°±)
3. GROUND ELEVATION:	206.0' A.M.S.L.
4. TAX MAP NUMBER:	SS189-
5. PARCEL AREA:	259.00 ACRES
6. PARCEL OWNER:	ALAN KINNEY, JR P.O. BOX 442 SOUTH HERO, VT 05486
7. ZONING DISTRICT:	RURAL RESIDENTIAL DISTRICT
8. STRUCTURE TYPE:	CONCRETE OR HARVESTORE SILO
9. STRUCTURE HEIGHT:	55.0' A.G.L. (TOP OF SILO)

THESE DRAWINGS ARE FORMATTED TO BE FULL SIZE AT 22"X34".
CONTRACTOR SHALL VERIFY ALL PLANS AND EXISTING DIMENSIONS AND
CONDITIONS ON THE JOB SITE AND SHALL IMMEDIATELY NOTIFY THE
DESIGNER/ENGINEER IN WRITING OF ANY DISCREPANCIES BEFORE
PROCEEDING WITH THE WORK OR MATERIAL ORDERS OR BE RESPONSIBLE
FOR THE SAME. CONTRACTOR SHALL USE THE STATE OF VERMONT LOW
RISK SITE HANDBOOK FOR EROSION PREVENTION AND SEDIMENT
CONTROL TO PREVENT STORM WATER POLLUTION DURING
CONSTRUCTION.

1. LAND OWNER: ALAN KINNEY, JR
P.O. BOX 442
SOUTH HERO, VT 05486

2. APPLICANT: BELL ATLANTIC MOBILE SYSTEMS OF
ALLENTOWN, INC. AND CELLCO PARTNERSHIP
EACH D/B/A VERIZON WIRELESS
C/O BRIAN SULLIVAN, ESQ., MURPHY SULLIVAN KRONK
P.O. BOX 4485, 275 COLLEGE STREET
BURLINGTON, VT 05401-4485
(802) 861-7000

3. ENGINEERING FIRM: DUBOIS & KING, INC.
6 GREEN TREE DRIVE
SOUTH BURLINGTON, VT 05403
(802) 878-7661



ALL WORK AND MATERIALS SHALL BE PERFORMED AND INSTALLED IN ACCORDANCE WITH THE CURRENT EDITIONS OF THE FOLLOWING CODES AS ADOPTED BY THE LOCAL GOVERNING AUTHORITIES. NOTHING IN THESE PLANS IS TO BE CONSTRUED TO PERMIT WORK NOT CONFORMING TO THE LATEST EDITIONS OF THE FOLLOWING CODES.

- | | |
|--|---|
| 1. 2015 INTERNATIONAL BUILDING CODE | 8. ANSI/TIA-222-G |
| 2. 2017 NATIONAL ELECTRICAL CODE | 9. TIA 607 |
| 3. NFPA 1 FIRE CODE, 2015 EDITION | 10. INSTITUTE FOR ELECTRICAL
& ELECTRONICS ENGINEER 81 |
| 4. NFPA 101 LIFE SAFETY CODE, 2015 EDITION | 11. IEEE C2 NATIONAL ELECTRIC
SAFETY CODE LATEST EDITION |
| 5. AMERICAN CONCRETE INSTITUTE | 12. TELECORDIA GR-1275 |
| 6. AMERICAN INSTITUTE OF STEEL CONSTRUCTION | 13. ANSI/T 311 |
| 7. MANUAL OF STEEL CONSTRUCTION 13TH EDITION | |

T-1	TITLE SHEET
C-1	OVERALL SITE PLAN
C-2	GENERAL NOTES
C-3	ABUTTER PLAN
C-4	DETAIL SITE PLAN
C-5	SOUTH SILO ELEVATION
C-6	EQUIPMENT SHELTER
C-7	CIVIL DETAILS
C-8	ANTENNA DETAILS
C-9	ANTENNA PLAN VIEW AND SUMMARY CHART
C-10	EPSC LOW RISK HANDBOOK
C-11	EPSC LOW RISK HANDBOOK
C-12	EPSC LOW RISK HANDBOOK
C-13	NOTICE TO CONTRACTOR
C-14	NOTICE TO CONTRACTOR
S-1	EQUIPMENT BUILDING PLANS AND SECTIONS
S-2	EQUIPMENT BUILDING ELEVATIONS AND NOT
E-1	ELECTRICAL SITE PLAN
E-2	SITE GROUNDING PLAN
E-3	ELECTRICAL DETAILS
E-4	ANTENNA EQUIPMENT DETAILS & SCHEMATIC
E-5	ELECTRICAL SPECIFICATIONS

EB-1	ELECTRICAL ABBREVIATIONS, LEGEND, AND GENERAL NOTES
EB-2	ELECTRICAL EXTERIOR ELEVATIONS
EB-3	ELECTRICAL INTERIOR FLOOR PLAN AND CEILING PLANS
EB-4	ELECTRICAL INTERIOR ELEVATIONS
EB-5	ELECTRICAL DETAILS
EB-6	ELECTRICAL SPECIFICATIONS
M-1	MECHANICAL NOTES, FLOOR PLAN, AND SCHEDULES

		APPROVED	APPROVED AS NOTED	DISAPPROVE REVISE
PROPERTY OWNER	DATE	☐	☐	☐
SITE ACQUISITION	DATE	☐	☐	☐
CONSTRUCTION MANAGER	DATE	☐	☐	☐
RF ENGINEER	DATE	☐	☐	☐

[illegible]

SOUTH HERO
2 VT

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE



TLE SHEE

CONSTRUCTION PLANS

DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

SHEET NUMBER

T-1



89 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE


OVERALL
SITE PLAN

CONSTRUCTION PLANS

DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

SHEET NUMBER

C-1



PROJECT LOCATION
LAT: 44°-37'-14.89"
LONG: 73°-18'-04.76"
ELEV: 206.0'±

SOUTH STREET

WHIPPLE ROAD

W SHORE ROAD



SOUTH STREET

1. TYPE OF PROJECT: TELECOMMUNICATIONS FACILITY
2. DESCRIPTION OF MAJOR PROJECT COMPONENTS: UNMANNED TELECOMMUNICATIONS FACILITY TO BE CONSTRUCTED ON A 259.00 ACRE PARCEL ON SOUTH STREET IN SOUTH HERO. THE PROPERTY MAINTAINS AN ACTIVE FARM. PROPOSED 12'x20' EQUIPMENT SHELTER TO BE CONSTRUCTED ON THE SOUTH SIDE OF THE EXISTING BARN, IN FRONT OF THE EXISTING GRAIN SILO. PROPOSED ANTENNAS AND EQUIPMENT TO BE MOUNTED ON THE PROPOSED SILO AT THE 50' A.G.L. ELEVATION. PROPOSED ELECTRIC AND TELEPHONE WILL CONNECT TO THE EXISTING UTILITY POLE EAST OF THE EXISTING HARVESTORE SILO.
3. POSTED SPEED LIMIT: 35 M.P.H.
4. TOTAL ACREAGE OF TEMPORARY EARTH DISTURBANCE: 1,136 S.F. (0.03 ACRES)
 - 4.1. STORMWATER CONSTRUCTION GENERAL PERMIT REQUIRED: NO
5. TOTAL ACREAGE OF TREE CLEARING: 0 S.F. (0.00 ACRES)
6. TOTAL AREA OF PERMANENT EARTH DISTURBANCE: 644 S.F. (0.01 ACRES)
7. IMPERVIOUS AREA
 - 7.1. EXISTING = AGRICULTURAL EXEMPTION
 - 7.2. PROPOSED = 644 S.F. (0.01 ACRES)
 - 7.3. TOTAL = 644 S.F. (0.01 ACRES)
 - 7.4. STORMWATER OPERATIONAL PERMIT REQUIRED: NO
8. SEQUENCE OF MAJOR PROJECT COMPONENTS:
 - 8.1. INSTALL PROPOSED SILO.
 - 8.2. INSTALL EQUIPMENT SHELTER.
 - 8.3. INSTALL UNDERGROUND FIBER TO ANTENNAS.
 - 8.4. INSTALL ANTENNAS AND EQUIPMENT TO PROPOSED SILO.
 - 8.5. CONNECT EQUIPMENT CABINET TO EXISTING ELECTRICAL/FIBER SERVICES.
9. PROPOSED POLLUTION PREVENTION STRATEGIES: CONTRACTOR TO ENSURE THAT THE SITE REMAINS CLEAN AND ALL DEBRIS AND UNUSED MATERIALS ARE REMOVED AT THE END OF EACH DAY.
10. MAXIMUM CONCURRENT EARTH DISTURBANCE: EARTH DISTURBANCE SHALL BE MINIMIZED AND STABILIZED AS SOON AS FEASIBLE. TOTAL EARTH DISTURBANCE SHALL NOT EXCEED 1 ACRE.
11. USE OF VEGETATED BUFFERS: THE PROJECT WILL NOT HAVE STORMWATER DISCHARGES FROM THE CONSTRUCTION SITE TO WETLANDS AND DRAINAGE CHANNELS FROM THE ACCESS ROAD THAT DO NOT FIRST FILTER THROUGH A 50 FT. VEGETATED BUFFER. THE ACCESS ROAD AND COMPOUND WILL BE GRADED TO PROVIDE A MILD CROSS-SLOPE TO DIRECT RUNOFF TO MAINTAIN EXISTING DRAINAGE PATHS.
12. NAME OF RECEIVING WATERS: UNNAMED TRIBUTARY TO LAKE CHAMPLAIN
13. NUMBER OF PROPOSED STREAM CROSSINGS: 0
 - 13.1. STREAM ALTERATION PERMIT REQUIRED: NO
14. WETLAND IMPACTS:
 - 14.1. AREA OF WETLANDS IMPACTED BY PROPOSED ACTIVITIES: 0 S.F. (0.00 ACRES)
 - 14.2. AREA OF WETLAND BUFFERS IMPACTED BY PROPOSED ACTIVITIES: 0 S.F. (0.00 ACRES)
 - 14.3. STATE WETLANDS PERMIT REQUIRED: NO
 - 14.4. ARMY CORPS OF ENGINEERS PERMIT REQUIRED: NO
15. RIVER AND STREAM IMPACTS: NONE
 - 15.1. LOCATED IN A FLOOD HAZARD AREA: NO
 - 15.2. LOCATED IN A RIVER CORRIDOR: NO
 - 15.3. LOCATED IN A RIPARIAN BUFFER: NO
16. RARE, THREATENED, OR ENDANGERED SPECIES IMPACTS: NONE
17. SIGNIFICANT NATURAL COMMUNITY: NO IDENTIFIED CONCERNS
18. WATER SUPPLY SOURCE PROTECTION AREA IMPACTS: NONE
19. NATURAL RESOURCES HABITAT IMPACTS:
 - 19.1. DEER WINTERING AREA: NO IDENTIFIED CONCERNS
 - 19.2. BEAR HABITAT AREA: NO IDENTIFIED CONCERNS
 - 19.3. SONG BIRD HABITAT AREA: NO IDENTIFIED CONCERNS
 - 19.4. BAT HABITAT AREA: NORTHERN LONG-EARED BAT
 - 19.5. HABITAT BLOCK: NO IDENTIFIED CONCERNS
 - 19.6. BIOFINDER: PRIORITY: NO IDENTIFIED CONCERNS
20. LOCAL ZONING – TOWN OF SOUTH HERO
 - 20.1. ZONING DISTRICT: RURAL RESIDENTIAL DISTRICT
 - 20.2. OVERLAY DISTRICT:
21. PROPERTY LINE INFORMATION PROVIDED BY THE TOWN OF SOUTH HERO TAX MAPS. DUBOIS & KING, INC. DID NOT PERFORM A BOUNDARY SURVEY.
22. TOPOGRAPHIC SURVEY PERFORMED BY DUBOIS & KING, INC. ON JULY 11, 2025.
23. THE PROJECT WILL COMPLY WITH THE LOW RISK HANDBOOK FOR EROSION PREVENTION AND SEDIMENT CONTROL BY THE VERMONT DEPARTMENT OF ENVIRONMENTAL CONSERVATION, 2020 EDITION.
24. ELEVATIONS FROM GPS OBSERVATIONS.

2. THE CONTRACTOR SHALL REVIEW ALL RELEVANT PERMITS ASSOCIATED WITH THIS PROJECT, AND IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO ASSURE ALL RELEVANT REQUIREMENTS REGARDING CONSTRUCTION, TESTING, AND REPORTING ARE MET. UPON REQUEST THE ENGINEER WILL FURNISH ALL COPIES OF THE RELEVANT PERMITS TO THE CONTRACTOR. UNLESS OTHERWISE DETERMINED, THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING AND INCURRING THE COST OF ALL RELEVANT FEDERAL, STATE AND LOCAL BUILDING PERMITS PRIOR TO COMMENCEMENT OF CONSTRUCTION. REQUIRED INSPECTIONS AND FEES ASSOCIATED WITH THESE INSPECTIONS, IF APPLICABLE, SHALL ALSO BE THE CONTRACTOR'S RESPONSIBILITY.
3. THE CONTRACTOR SHALL NOTIFY DIG SAFE ☎ 1-888-344-7233 AT LEAST FORTY-EIGHT (48) HOURS PRIOR TO EXCAVATION.
4. THE CONTRACTOR SHALL NOTIFY THE ENGINEER AND VERIZON WIRELESS IN WRITING OF SITE CONDITIONS THAT VARY MATERIALLY FROM WHAT IS SHOWN ON THESE DRAWINGS. WRITTEN APPROVAL FROM THE ENGINEER IS REQUIRED TO DEViate FROM THESE DRAWINGS.
5. ALL MATERIAL TO BE USED FOR YARD CONSTRUCTION SHALL CONFORM TO THE SPECIFICATION CONTAINED HEREON OR APPROVED IN WRITING BY THE ENGINEER. IT IS THE CONTRACTOR'S RESPONSIBILITY TO SECURE THIS APPROVAL. A SAMPLE OF BASE MATERIAL IS REQUIRED TO BE TESTED FOR CONFORMANCE WITH THE STANDARDS OUTLINED ON THESE PLANS, BY AN APPROVED MATERIALS TESTING LABORATORY. TESTING OF ALL BASE MATERIALS SHALL BE AT THE CONTRACTOR'S EXPENSE.
6. THE CONTRACTOR SHALL RESTORE ALL PUBLIC OR PRIVATE PROPERTY DAMAGED AS A RESULT OF CONSTRUCTION TO A CONDITION EQUAL TO OR BETTER THAN BEFORE THE SITE WAS DISTURBED. THIS SHALL INCLUDE THE ACCESS ROAD TO THE SITE. ALL EXISTING SERVICES AND ACCESS TO THE EXISTING FACILITY LOCATED ON THE SITE MUST BE MAINTAINED THROUGHOUT CONSTRUCTION.
7. UTILITY CONNECTIONS AND TIE-INS SHALL BE COORDINATED WITH THE ENGINEER, THE BUILDING OWNER, AND THE UTILITY. THE CONTRACTOR SHALL MEET APPLICABLE UTILITY STANDARDS.
8. THE CONTRACTOR SHALL COOPERATE AND COORDINATE FULLY WITH ALL OTHER CONTRACTORS WORKING ON THIS SITE. THE CONTRACTOR SHALL ALSO COOPERATE WITH THE OWNER OF THE SITE PARCEL AND THE OWNER OF THE PROPERTY ON WHICH THE ACCESS ROAD IS LOCATED.
9. AS-BUILT DRAWINGS ARE REQUIRED AT THE COMPLETION OF THE PROJECT. THE CONTRACTOR SHALL NOTE ALL DEVIATIONS FROM THE DRAWINGS, AND LOCATE ALL SUBSURFACE CONSTRUCTION ON THE AS-BUILT DRAWINGS. APPROVAL AND ACCEPTANCE OF THESE DRAWINGS WILL BE REQUIRED PRIOR TO FINAL PAYMENT.
10. SURFACE DRAINAGE SHALL BE CONTROLLED DURING CONSTRUCTION TO PERMIT PROPER CONSTRUCTION. FINAL (FINISHED) GRADES SHALL BE GRADED TO PROVIDE POSITIVE DRAINAGE AWAY FROM PROPOSED AND EXISTING BUILDINGS, AND TOWER.
11. EXISTING MONUMENTATION SHALL NOT BE DISTURBED OR DESTROYED. THE CONTRACTOR IS RESPONSIBLE FOR REPLACING ANY MONUMENTATION DISTURBED DURING THE COURSE OF CONSTRUCTION. THE MONUMENTATION SHALL BE REPLACED UNDER THE SUPERVISION OF A VERMONT STATE LICENSED LAND SURVEYOR.

	APPROXIMATE PROPERTY LINE
	OVERHEAD UTILITY LINE
	EXISTING TREE LINE
	DELINEATED STREAM
	RIPARIAN BUFFER
	50' WETLAND BUFFER
	DELINEATED WETLAND
	MINOR CONTOUR LINE
	MAJOR CONTOUR LINE
	UTILITY POLE
	BENCHMARK
	DECIDUOUS TREE
	EVERGREEN TREE

	LIMITS OF DISTURBANCE
	LIMITS OF CONSTRUCTION
	REINFORCED SILT FENCE
	PROPOSED TILT LINE
	UNDERGROUND ELEC & TEL LINE
	CHAIN LINK FENCE
	PROPOSED UTILITY POLE
	PROPOSED WATER BAR
	TEMPORARY WATER BAR



189 SOUTH STREET
SOUTH HERO, VT
05486

GENERAL NOTES

DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

C-2



- ABUTTER LIST:
- | | |
|--|--|
| A. PARCEL #: SS169—
N/F SUNSET LAKE FARM #2, LLC
25 BREWER PARKWAY
S. BURLINGTON, VT 05403 | Q. PARCEL #: WH008—
N/F WILLIAM & MARILEE CAIN
8 WHIPPLE ROAD
SOUTH HERO, VT 05486 |
| B. PARCEL #: LR064—
N/F MAUREEN PIDGEON
64 LONDON ROAD
SOUTH HERO, VT 05486 | R. PARCEL #: WH004—
N/F AFEWORK & CHARLOTTE HAGOS
4 WHIPPLE ROAD
SOUTH HERO, VT 05486 |
| C. PARCEL #: WH085—
N/F CHRISTIAN LEVESQUE &
CHRISTINE LEBIECKI
85 WHIPPLE ROAD
SOUTH HERO, VT 05486 | S. PARCEL #: SS224—
N/F WILLIAM & REINA WARREN
224 SOUTH STREET
SOUTH HERO, VT 05486 |
| D. PARCEL #: WH075—
N/F CHARLES & SUSAN HILL
75 WHIPPLE ROAD
SOUTH HERO, VT 05486 | T. PARCEL #: SS220—
N/F DAVID PLOOF
220 SOUTH STREET
SOUTH HERO, VT 05486 |
| E. PARCEL #: WH074—
N/F MICHAEL & MARY SANTOR
74 WHIPPLE ROAD
SOUTH HERO, VT 05486 | U. PARCEL #: SS154—
N/F RAY ALLEN
P.O. BOX 300
SOUTH HERO, VT 05486 |
| F. PARCEL #: WH058—
N/F RICHARD ALARIE
58 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| G. PARCEL #: WH052—
N/F DANIEL LIVERSEEDGE &
MELANIE HENDERSON
52 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| H. PARCEL #: WH050—
N/F DAVID & SARA KIRK
4933 CARTERET DRIVE
RALEIGH, N.C. 27612 | |
| I. PARCEL #: WH040—
N/F JONATHAN & MICHELLE McKAY
40 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| J. PARCEL #: WH044—
N/F WIRSING FAMILY REV. TRUST
44 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| K. PARCEL #: WH030—
N/F RICHARD GOGGIN—TOBEY
30 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| L. PARCEL #: WH026—
N/F DOUGLAS & DEBRA PLUMLEY
26 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| M. PARCEL #: WH024—
N/F PETER & LINDA LAWRENCE
24 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| N. PARCEL #: WH022—
N/F MATTHEW PERREAULT
22 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| O. PARCEL #: WH020—
N/F MICHAEL & CYNTHIA O'HARA
20 WHIPPLE ROAD
SOUTH HERO, VT 05486 | |
| P. PARCEL #: WH014—
N/F ROBERT BOISSEVAIN
126 PENDLETON HILL ROAD
NORTH STONINGTON, CT 06359 | |

DuBois & King inc.

ENGINEERING • PLANNING •
MANAGEMENT • DEVELOPMENT

6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 782-7661
FAX: (866) 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BRANDON, VT
BEDFORD, NH
LACONIA, NH
© Copyright 2025 Dubois & King Inc.

[illegible]

PROJECT ID:
PROJECT TYPE:
LOCATION CODE:

**SOUTH HERO
2 VT**

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE	
-------------	--


ABUTTER
PLAN



Downloaded from ascelibrary.org by University of California, San Diego on 06/01/15. Copyright ASCE, For All Rights Reserved, No part of this document may be reproduced without written permission from ASCE.

CONSTRUCTION PLANS	
DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

SHEET NUMBER

C-3







189 SOUTH STREET
SOUTH HERO, VT
05486

DETAIL SITE PLAN

DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

C-4








189 SOUTH STREET
SOUTH HERO, VT
05486

SOUTH
SILO
ELEVATION

DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

C-5








189 SOUTH STREET
SOUTH HERO, VT
05486

QUIPMEN
SHELTER


DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

C-6








- NOTES:
1. SEED AND MULCH ALL EXPOSED SOILS AS SOON AS FEASIBLE.
 2. CONTRACTOR TO FOLLOW STATE OF VERMONT LOW RISK HANDBOOK FOR EROSION PREVENTION AND SEDIMENT CONTROL.



- NOTES:**
1. WHERE BACKFILL IS DESIGNATED "COMPACTED", THIS MEANS 90% TO 95% STANDARD PROCTOR, AASHTO T-99. ALL FILL PLACED BELOW PIPES MUST MEET THIS REQUIREMENT.
 2. SUITABLE MATERIAL SHALL CONTAIN NO STONES GREATER THAN 4" IN DIAMETER, NO FROZEN LUMPS, AND ONLY MINOR AMOUNTS OF CLAY OR ORGANIC MATERIAL. ALL MATERIAL TO BE PLACED IN MAXIMUM OF 12" LIFTS AND COMPACTED BEFORE PLACING NEXT LIFT.
 3. SEE ELECTRICAL PLANS FOR QUANTITY OF CONDUITS.




- NOTE:
1. TYPICAL DESIGN FOR REFERENCE ONLY. FINAL DESIGN TO BE DETERMINED BASED ON FINAL SILO CONFIGURATION.



**DuBois
& King inc.**

ENGINEERING • PLANNING •
MANAGEMENT • DEVELOPMENT
6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 878-7661
FAX: (866) 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BRANDON, VT
BEDFORD, NH
LACONIA, NH
© Copyright 2005 Dubois & King Inc.

[illegible]

PROJECT ID:
PROJECT TYPE:
LOCATION CODE:

**SOUTH HERO
2 VT**

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE	
-------------	--


CIVIL
DETAILS

CONSTRUCTION PLANS


DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #

SHEET NUMBER	
--------------	--

C-7




SAMSUNG MT6413-77A
PANEL ANTENNA DETAIL
NOT TO SCALE



12 PORT OVP DISTRIBUTION BOX DETAIL
NOT TO SCALE

NOTES:


1. REFER TO MOUNT DESIGN AND ANALYSIS REPORT BY _____, DATED _____, FOR ANY REQUIRED MODIFICATIONS.



FRONT ELEVATION SIDE VIEW

QS6656-5DL

PANEL ANTENNA DETAILS
NOT TO SCALE




PROPOSED ANTENNA DETAILS
NOT TO SCALE

PROPOSED QS6656-5DL ANTENNA
MOUNTED ON STD. 2-3/8" SCH.
40 PIPE, 9' LONG
(TYP. 2 PER SECTOR, 6 TOTAL)


PROPOSED MOUNTING BRACKET

PROPOSED SAMSUNG RRH
RF4461d-13A
H14.96" X W14.96" X D10.23"
(TYP. OF 2)





SAMSUNG RRH B5/B13
RF4461d-13A 700/850 DETAIL
NOT TO SCALE


PROPOSED SAMSUNG RRH
RF4439d-25A ORAN
H14.96" X W14.96" X D10.04"
(TYP. OF 2)



SAMSUNG RRH B2/B66A
RF4439d-25A PCS/AWS DETAIL
NOT TO SCALE



RRH MOUNT
NOT TO SCALE



RRH MOUNTING DETAIL
NOT TO SCALE

DuBois & King inc.

ENGINEERING • PLANNING •
MANAGEMENT • DEVELOPMENT
6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 878-7661
FAX: (866) 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BRANDON, VT
BEDFORD, NH
LACONIA, NH
© Copyright 2025 Dubois & King Inc.



NO.	DATE	ISSUED FOR BID	BY	CK'D
1	12-19-2025		JWP	LJH



**SOUTH HERO
2 VT**

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE



ANTENNA
DETAILS

CONSTRUCTION PLANS

DRAWN BY	DATE
JWP	DEC. 2025
CHECKED BY	D&K PROJECT #
LJH	430115L
PROJ. ENG.	D&K ARCHIVE #
LJH	

SHEET NUMBER

C-8



189 SOUTH STREET
SOUTH HERO, VT
05486


SHEET TITLE

ANTENNA PLAN VIEW AND SUMMARY CHART

CONSTRUCTION PLANS

SHEET NUMBER

C-9



NOTE:
ANTENNA AND EQUIPMENT CONFIGURATION
BASED ON RFDS DATED APRIL 5, 2024.

to FUZE Site Project Management (SPM) Module along with the EES Close-Out Notification.

Contractor's Signature	
Contractor's Printed Name	
Date	
Company Name	
Company Address	
Phone Number	

to FUZE Site Project Management (SPM) Module along with the EES Close-Out Notification.

Contractor's Signature	
Contractor's Printed Name	
Date	
Company Name	
Company Address	
Phone Number	



**DuBois
& King inc.**

ENGINEERING • PLANNING •
MANAGEMENT • DEVELOPMENT

[illegible]

**SOUTH HERO
2 VT**

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE	
-------------	--







NOTICE TO
CONTRACTOR

CONSTRUCTION PLANS

DRAWN BY JWP	DATE DEC. 2025
CHECKED BY LJH	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE #






SHEET NUMBER

C-14



(S-1) 1" = 1'-0"

$$\text{S-1} \quad 1'' = 1'-0''$$



NOTE:
PER OWNERS REQUEST STRUCTURE IS NOT DESIGNED FOR FROST PROTECTION. STRUCTURE MAY SHIFT DURING FREEZE AND THAW CYCLES RESULTING IN THE STRUCTURE NOT BEING LEVEL AND FOUNDATION SLAB MAY BE SUBJECT TO CRACKING.

GENERAL

- USE STRUCTURAL DRAWINGS IN CONJUNCTION WITH THE SPECIFICATIONS AND MECHANICAL, ELECTRICAL AND CIVIL DRAWINGS.
- PERFORM ALL WORK IN ACCORDANCE WITH APPLICABLE CODES.
- DO NOT SCALE DIMENSIONS FROM DRAWINGS.
- DETAILS SHOWN ARE TYPICAL, UNLESS NOTED OTHERWISE.
- VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS, AND REPORT DISCREPANCIES TO ENGINEER BEFORE PROCEEDING WITH THE WORK.

EARTHWORK

- COMPACTED CRUSHED STONE MATERIAL: WASHED, NARROWLY GRADED MIXTURE OF CRUSHED STONE OR GRAVEL, ASTM D448 COARSE AGGREGATE GRADING SIZE 57 WITH 100% PASSING A 1 1/2" SIEVE AND 0%-5% PASSING A NO. 8 SIEVE.
- FOOTINGS/SLABS: PLACE FOOTING/SLABS ON COMPACTED CRUSHED STONE FILL. ASSUMED BEARING CAPACITY FOR FOUNDATION DESIGN IS 2000 POUNDS PER SQUARE FOOT.
- SEPARATION GEOTEXTILE: NON-WOVEN GEOTEXTILE FABRIC, MANUFACTURED FOR SEPARATION APPLICATIONS, COMPLYING WITH VTRANS SPECIFICATION ITEM 649.31 GEOTEXTILE UNDER STONE FILL.

CONCRETE

- ALL CONCRETE SHALL CONFORM TO REQUIREMENTS AND RECOMMENDATIONS OF ACI 318 "BUILDING CODE REQUIREMENTS OF REINFORCED CONCRETE" AND TO ACI FIELD REFERENCE MANUAL SP-15.
- CONCRETE WORK SHALL CONFORM TO ALL REQUIREMENTS OF ACI 301 "SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS", EXCEPT AS MODIFIED OR SUPPLEMENTED BELOW.
- CONCRETE COMPRESSIVE DESIGN STRENGTH AND MIX PROPORTIONS SHALL BE AS OUTLINED BELOW. MIX PROPORTIONS AND DESIGNS SHALL BE SUBMITTED FOR APPROVAL. LIMIT MAXIMUM WATER-SOLUBLE CHLORIDE ION CONTENT IN CONCRETE BY WEIGHT OF CEMENT FOR CAST-IN-PLACE CONCRETE TO 0.15 FOR ALL CONCRETE.

INTERIOR SLABS ON GRADE:
CONCRETE CLASS: F2, S0, W1, C1
COMPRESSIVE STRENGTH = 4,500 PSI
MAX. W/CM RATIO = 0.45
AIR CONTENT = ≤ 3%

EXTERIOR SLABS ON GRADE:
CONCRETE CLASS: F3, S0, W1, C2
COMPRESSIVE STRENGTH = 5,000 PSI
MAX. W/CM RATIO = 0.40
AIR CONTENT = 6% +/- 1.5%

- ALL CONCRETE SHALL BE READY-MIX CONCRETE CONFORMING TO ASTM C94, EXCEPT THAT ADDITION OF WATER WILL NOT BE PERMITTED.
- CONCRETE SLABS SHALL BE WET CURED. USE OF MEMBRANE-FORMING CURING COMPOUND IS PROHIBITED.
- INTERIOR SLABS SHALL RECEIVE A FLOAT FINISH. EXTERIOR SLABS SHALL RECEIVE A BROOM FINISH.
- INTERIOR SLABS SHALL RECEIVE A PENETRATING FLOOR SEALER. APPLY ASHFORD FORMULA OR APPROVED EQUAL TO EXPOSED CONCRETE SURFACES IN STRICT COMPLIANCE WITH MANUFACTURER'S RECOMMENDATIONS.
- REINFORCING STEEL: ASTM A615 GRADE 60.

WOOD FRAMING

- ALL WOOD CONSTRUCTION SHALL CONFORM TO THE REQUIREMENTS OF THE "NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION" BY THE NATIONAL FOREST PRODUCTS ASSOCIATION AND TO LOCAL BUILDING CODES.
- ALL WOOD MEMBERS SHALL BE SPRUCE-PINE-FIR, NO. 2 GRADE OR BETTER.
- ALL PRESSURE TREATED WOOD MEMBERS SHALL BE SOUTHERN PINE NO. 2 GRADE OR BETTER. ALL METAL CONNECTORS, ANCHORS AND FASTENERS USED FOR PRESERVATIVE TREATED WOOD SHALL BE STAINLESS STEEL OR HOT-DIPPED GALVANIZED AS RECOMMENDED BY THE CONNECTOR, ANCHOR OR FASTENER MANUFACTURER.
- ALL WOOD HEADERS AT BEARING WALLS SHALL BE A MINIMUM OF (2) 2x8's, UNLESS NOTED OTHERWISE. WOOD MEMBERS USED FOR HEADERS, OR BUILT-UP BEAMS SHALL NOT HAVE CHECKS OR SPLITS LONGER THAN THE WIDE FACE WIDTH.
- EXTERIOR WALL SHEATHING SHALL BE 1/2" ADVANTECH ZIP SYSTEM.

BUILDING MATERIALS

- FINISHES:
 - ROOFING: MINIMUM 24 GAGE CORRUGATED METAL OVER GRACE ICE & WATER SHIELD WITH EXPOSED FASTENERS.
 - WALLS: MINIMUM 24 GAGE CORRUGATED METAL WITH EXPOSED FASTENERS. SEE DETAILS.
 - CEILINGS: NONE
 - FLOOR: CONCRETE SLAB. SEE CONCRETE NOTE #6 ABOVE.
 - ALL EXPOSED FASTENERS SHALL BE MANUFACTURED FOR CONTINUOUS EXPOSURE AND HAVE AN INTEGRAL RUBBER GASKET DESIGNED TO SEAL THE FASTENER PENETRATION THROUGH THE CORRUGATED METAL.
- LOUVERS: REFER TO MECHANICAL DRAWINGS.

DESIGN CRITERIA

- CODES: IBC 2015 AND ASCE 7-10, AS AMENDED BY THE 2015 VERMONT FIRE AND BUILDING SAFETY CODE.
- BUILDING/STRUCTURE RISK CATEGORY: III.

- ROOF LOADS:

RAFTER DEAD:	8 PSF
CEILING DEAD:	8 PSF
ROOF LIVE:	20 PSF
- SNOW LOADS:

GROUND SNOW:	Pg = 40 PSF
EXPOSURE FACTOR:	Ce = 1.2
THERMAL FACTOR:	Ct = 1.2
IMPORTANCE FACTOR:	Is = 1.10
FLAT ROOF SNOW LOAD:	Pf = 40 PSF
SLOPED ROOF SNOW LOAD:	Ps = 40 PLUS DRIFT AS REQUIRED

- FLOOR LIVE LOADS: 100 PSF

- WIND LOADS:

WIND SPEED:	V = 120 MPH
NOMINAL WIND SPEED:	V _{ASD} = 93 MPH
EXPOSURE:	C
INTERNAL PRESSURE COEFFICIENT:	GCpi = +/- 0.18
COMPONENTS AND CLADDING:	ASCE 7-10

- SEISMIC LOADS:


IMPORTANCE FACTOR:	Ie = 1.25
MAPPED SPECTRAL RESPONSE COEFFICIENTS:	S _s = 0.393, S ₁ = 0.113
SITE CLASS:	D (ASSUMED PER IBC 1618.3.2)
SPECTRAL RESPONSE COEFFICIENTS:	S _{DS} = 0.389, S _{D1} = 0.177
SEISMIC DESIGN CATEGORY:	C
SEISMIC FORCE RESISTING SYSTEM:	BEARING WALL SYSTEM WITH LIGHT-FRAMED WOOD WALLS SHEATHED WITH WOOD STRUCTURAL PANELS RATED FOR SHEAR RESISTANCE WITH R = 6.5.
SEISMIC BASE SHEAR:	V = 0.075W
ANALYSIS PROCEDURE:	EQUIVALENT LATERAL FORCE

DuBois & King inc

ENGINEERING • PLANNING
MANAGEMENT • DEVELOPMENT
6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 878-7661
FAX: (802) 866 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BRANDON, VT
BEFORD, NH
LACONIA, NH

© Copyright 2025 Dubois & King Inc.

PROFESSIONAL SEAL



NO.	DATE	DESCRIPTION	BY
			CKD



PROJECT ID:
PROJECT TYPE:
LOCATION CODE:

SOUTH HERO 2, VT

189 SOUTH STREET
SOUTH HERO, VT 05486

SHEET TITLE

EQUIPMENT
BUILDING
ELEVATIONS AND
NOTES


CONSTRUCTION PLANS

DRAWN BY	DATE
MDL	07/15/2025
CHECKED BY	D&K PROJECT #
TWD	430115
PROJ. ENG.	D&K ARCHIVE #
MDL	


SHEET NUMBER

S-2

SHEET 2 OF 2



- DuBois & King inc.**
- ENGINEERING • PLANNING •
MANAGEMENT • DEVELOPMENT
- 6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 878-7661
FAX: (866) 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BRANDON, VT
BEDFORD, NH
LACONIA, NH
- © Copyright 2025 Dubois & King Inc.
- STATE OF VERMONT**
JAN 10 2025
No. 14730
ELECTRICAL
LICENSED
PROFESSIONAL ENGINEER

[illegible]

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE	
-------------	--

CONSTRUCTION PLANS

DRAWN BY EJD	DATE AUG. 2025
CHECKED BY	D&K PROJECT # 430115L
PROJ. ENG. LJH	D&K ARCHIVE # 7877

SHEET NUMBER


E-1



(E-1) SCALE: NO SCALE

ELECTRICAL UTILITY (GMP) PREFERENCES THAT THE VERIZON SERVICE CONNECTION COME FROM THE UTILITY POLE AT THE STREET. THERE ARE EXISTING ALUMIFORM BRACKETS FOR THE T-MOBILE SERVICE ON THE EXISTING POLE. THE VERIZON SERVICE MUST RISE UP ON THOSE BRACKETS. CONDUIT RISE SHOULD BE SCHEDULE 80 AND EXTEND A MINIMUM 36" UP THE POLE ADJACENT TO EXISTING T-MOBILE SERVICE RISER.


E-2




NOTES:

- UTILITY METERING PER LATEST UTILITY COMPANY STANDARDS.
- DETAIL INFORMATION TAKEN FROM VERMONT UTILITIES ELECTRIC SERVICE REQUIREMENTS MANUAL.

1 TYPICAL SERVICE BACKBOARD DETAIL
E-3 NOT TO SCALE




4 BLDG SERVICE ENTRANCE DETAIL
E-3 NOT TO SCALE



NOTES:

- BOND ANTENNA GROUNDING KIT CABLE TO GROUND BAR (GND BAR).
- ALL CELL EQUIPMENT (BTS, BATTERY FRAME, POWER CABINETS, MISC. EQUIPMENT FRAMES, ETC.) SHALL BE GROUNDED IN ACCORDANCE WITH MANUFACTURER SPECIFICATIONS.
- GROUND ANTENNA SUPPORT PIPES (TYP. 4 PER SECTOR) WITH #2 AWG TINNED BCW DEDICATED LEAD BACK TO GROUND BAR.


2 GROUNDING DIAGRAM
E-3 NOT TO SCALE




NOTES:

- THE ELEVATION AND LOCATIONS OF THE GPS ANTENNA SHALL BE IN ACCORDANCE WITH THE FINAL RF REPORT.
- PROVIDE MOUNTING POST ON ROOF, FOR GPS ANTENNA IN ACCORDANCE WITH VERIZON SPECIFICATIONS.
- THE GPS ANTENNA MOUNT IS DESIGNED TO FASTEN TO A STANDARD 2-1/2" DIAMETER, SCHEDULE 40, GALVANIZED STEEL OR STAINLESS STEEL PIPE. THE PIPE MUST NOT BE THREADED AT THE ANTENNA MOUNT END. THE PIPE SHALL BE CUT TO THE REQUIRED LENGTH (MINIMUM 24") USING A HAND OR ROTARY PIPE CUTTER TO ASSURE A SMOOTH AND PERPENDICULAR CUT. A HACK SAW SHALL NOT BE USED. THE CUT PIPE END SHALL BE DE-BURRED AND SMOOTH IN ORDER TO SEAL AGAINST THE NEOPRENE GASKET ATTACHED TO THE ANTENNA MOUNT.
- PRIOR TO INSTALLATION CONTRACTOR SHALL TEST GPS LOCATION WITH HAND HELD GPS AND MOVE GPS ANTENNA TO LOCATIONS AS REQUIRED TO ACHIEVE ADEQUATE SIGNAL. FAILURE TO ACHIEVE ADEQUATE SIGNAL WITH A HAND HELD GPS SHALL BE REPORTED TO CONSTRUCTION MANAGER AND ENGINEER TO DETERMINE ALTERNATE INSTALLATION LOCATION FOR GPS ANTENNA.

5 GPS GROUNDING/MOUNTING BRACKET DETAIL
E-3 NOT TO SCALE



3 GROUND BAR PLATE DETAIL
E-3 NOT TO SCALE







6 ICE BRIDGE DETAIL
E-3 NOT TO SCALE

NO.	DATE	ISSUED FOR BID	BY	CHK'D
1	8-04-2025		JWP	

DRAWN BY	DATE
EJD	AUG. 2025
CHECKED BY	D&K PROJECT #
WHH	430115L
PROJ. ENG.	D&K ARCHIVE #
LJH	7881

I:\A\430115 Verizon South Hero 2 VTL.dwg Construction Plans\CS0115_BOM.dwg 12/19/2025 6:40 AM




GENERAL NOTES:

- CONTRACTOR SHALL REFER TO THE LATEST VERIZON WIRELESS RF DATA SHEET WHICH MAY INCLUDE ANTENNA SECTOR AZIMUTHS/ANTENNA CHANGES, ETC. THAT ARE REQUIRED AS PART OF THE PROJECT.
- CONTRACTORS SHALL SECURE ALL CONTROL CABLES IN ACCORDANCE WITH INDUSTRY STANDARDS AND MANUFACTURERS INSTRUCTIONS. EXTERIOR CONTROL CABLES MAY BE TAPED OR TIE-WRAPPED TO EXISTING COAXIAL CABLES EVERY 4 FT. MAX. FOR HORIZONTAL RUNS. CONTRACTOR MAY USE HOISTING GRIPS AT TOP OF VERTICAL CABLE RUNS IN CERTAIN APPLICATIONS.
- CONTRACTOR SHALL VERIFY ALL CABLE LENGTHS PRIOR TO CONSTRUCTION.
- CABLE LENGTH BASED ON RRUS LOCATION ON BACKSIDE OF ANTENNA MASTS.

BILL OF MATERIALS

SITE NAME: SOUTH HERO 2 VT

ITEM	DESCRIPTION	QTY	LENGTH	MODEL NUMBER	COMMENTS	SUPPLIED BY
1	PORT TERMINAL CAP	0	-	-	-	CONTRACTOR
2	1/2" FOAM COAX JUMPER	36	2m-6.56ft	-	-	VERIZON WIRELESS
3	POWER CABLE	9	180ft	-	-	VERIZON WIRELESS
4	FIBER CABLE	9	180ft	-	-	VERIZON WIRELESS
5	UPPER OVP	3	-	-	6-PORT	VERIZON WIRELESS
6	6x12 HYBRID CABLE	3	150ft	-	-	VERIZON WIRELESS
7	6x12 HYBRID CABLE	3	130ft	-	-	VERIZON WIRELESS
8	6x12 HYBRID CABLE	3	130ft	-	-	VERIZON WIRELESS
9	GROUNDING KIT	9	-	-	3 PER CABLE	CONTRACTOR
10	RRH	3	-	SAMSUNG RF4461d-13A B5/B13 RRH	700/850	VERIZON WIRELESS
11	RRH	3	-	SAMSUNG RF4439d-25A B2/B66A RRH	PCS/AWS	VERIZON WIRELESS
12	ANTENNA	6	-	NHH-65B-R2B	700/850/PCS/AWS	VERIZON WIRELESS
13	MMU	3	-	SAMSUNG MT6413-77A	5G	VERIZON WIRELESS
14	EQUIPMENT RACK	1	-	-	2 OVP/BBU EQUIPMENT RACK	VERIZON WIRELESS
15	EQUIPMENT RACK	1	-	-	BATTERY CABINET	VERIZON WIRELESS
16	GPS CABLE	1	25ft	-	-	VERIZON WIRELESS
17	GPS ANTENNA	1	-	-	-	VERIZON WIRELESS



DuBois & King inc.

ENGINEERING • PLANNING • MANAGEMENT • DEVELOPMENT

6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 878-7861
FAX: (866) 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BRANDON, VT
BEDFORD, NH
LACONIA, NH
© Copyright 2025 Dubois & King Inc.

PROFESSIONAL SEAL
STATE OF VERMONT
No. 53199
Civil Engineer

NO.	DATE	DESCRIPTION	BY	CHKD
1	12-19-2025	ISSUED FOR BID	JWP	LJH

PROJECT ID:
PROJECT TYPE:
LOCATION CODE:

SOUTH HERO 2 VT

189 SOUTH STREET
SOUTH HERO, VT
05486

SHEET TITLE

ANTENNA EQUIPMENT DETAILS & SCHEMATICS

CONSTRUCTION PLANS

DRAWN BY	DATE
JWP	DEC. 2025

CHECKED BY	D&K PROJECT #
LJH	430115L

PROJ. ENG.	D&K ARCHIVE #
LJH	

SHEET NUMBER

E-4

1.01 WORK INCLUDED

A. COMPLYING WITH THE APPLICABLE PROVISIONS OF THE GENERAL CONDITIONS, SUPPLEMENTARY CONDITIONS, SPECIAL STATE CONDITIONS AND OTHER PROVISIONS OF THE CONTRACT DOCUMENTS THAT APPLY TO THE WORK INCLUDED IN DIVISION 26. THE GENERAL PROVISIONS OF THE CONTRACT, INCLUDING THE GENERAL, SUPPLEMENTARY, AND SPECIAL CONDITIONS, AND THE OTHER PROVISIONS REQUIRE CONTRACTORS TO APPLY TO THE WORK SPECIFIED IN ALL SECTIONS OF THIS DIVISION.

B. THE WORK REQUIRED OF THIS DIVISION SHALL INCLUDE ALL LABOR, MATERIALS, EQUIPMENT, TRANSPORTATION AND ALL NECESSARY AND RELATED ITEMS REQUIRED TO PROVIDE COMPLETE AND SATISFACTORY OPERATING ELECTRICAL SYSTEMS FOR THE PROJECT, INSTALL NEW ELECTRICAL SYSTEMS INCLUDING BUT NOT LIMITED TO: SELECTIVE DEMOLITION, POWER DISTRIBUTION, ELECTRICAL DEVICES AND RECEPTACLES, LIGHTING, EMERGENCY LIGHTING, EXIT SIGNS, PANELBOARD, FIRE ALARM NOTIFICATIONS, BRANCH CIRCUIT WIRING, CAT 6 CABLES, SWITCHING, GROUNDING, AND POWER SYSTEMS FOR THE SYSTEM UPGRADES AND ADDITIONS/MODIFICATIONS.

C. THE WORK IN GENERAL INCLUDES, BUT IS NOT LIMITED TO, THE FOLLOWING:

1. WIRE AND CABLE.
2. WIRING DEVICES, RACEWAYS, BOXES AND FITTINGS.
3. BRANCH CIRCUITS TO ALL ELECTRICAL EQUIPMENT.
4. PANELBOARD AND CIRCUIT BREAKERS.
5. DISCONNECT SWITCHES AND FUSES.
6. LIGHTING SYSTEM, FIXTURES AND ACCESSORIES.
7. FINAL CONNECTIONS TO ALL EQUIPMENT FURNISHED BY THIS DIVISION AND BY OTHER DIVISIONS.
8. GROUNDING AND BONDING
9. RECEIVING, HANDLING AND STORAGE OF ALL EQUIPMENT REQUIRED OF THIS DIVISION
10. MOUNTING OF EQUIPMENT FURNISHED BY OTHER TRADES, IF SO DESIGNATED
11. THE FINAL TESTING AND ADJUSTMENT OF ALL ELECTRICAL SYSTEMS AND EQUIPMENT TO DEMONSTRATE PROPER FUNCTION, CONTROL AND INTERLOCK.
12. ALL MINOR AND RELATED ITEMS AND ACCESSORIES TO MAKE EACH SYSTEM COMPLETE IN ALL RESPECTS

D. DRAWINGS: CONTRACT DRAWINGS FOR ELECTRICAL WORK ARE IN PART DIAGRAMMATIC, INTENDED TO CONVEY SCOPE OF WORK AND INDICATE THE GENERAL ARRANGEMENT OF EQUIPMENT. ELECTRICAL TRADE SHALL FOLLOW THE FIELD CHANGES IN RELATING TO THEIR WORK. CONSULT WITH THE CONSTRUCTION DRAWINGS TO FAMILIARIZE THEMSELVES WITH CONDITIONS AFFECTING THEIR WORK, AND SHALL VERIFY SPACES IN WHICH THEIR WORK WILL BE INSTALLED BY MEASUREMENTS ON THE JOB AND NOT SCALE DRAWINGS.

E. COORDINATE ALL WORK ACTIVITIES WITH THE OWNER.

F. CONTRACTOR SHALL COORDINATE WITH OWNER WHEN ANY SHUTDOWNS OR POWER OUTAGES ARE REQUIRED. FAILURE TO DO SO, AND ANY SUBSEQUENT EXPENSES DUE TO FAILURE, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

G. CONTRACTOR SHALL COORDINATE WITH UTILITIES, AND THE OWNER OR ANY OTHER CUSTOMERS AFFECTED BY WORK. FAILURE TO DO SO, AND ANY SUBSEQUENT EXPENSES DUE TO FAILURE, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

H. COORDINATION WITH LOCAL FIRE DEPARTMENT PRIOR TO INSTALLATION OF ALL TYPES OF ALARM DEVICES.

I. THROUGHOUT CONSTRUCTION CONTRACTOR SHALL PROVIDE UPGRADED SCHEDULES TO ACCURATELY REFLECT TIME FRAME OF WORK.

J. COMPLYING WITH REQUIREMENTS OF ALL CODES AND REGULATORY AGENCIES.

K. ARRANGING FOR AND PAYING ALL FEES FOR PERMITS AND OBSERVATIONS.

L. INSTALLING EQUIPMENT FURNISHED BY OTHERS:

1. INSTALLING AND CONNECTING ELECTRICALLY OPERATED EQUIPMENT, CABINETS, STARTERS, CONTROLS AND RELATED ITEMS FURNISHED UNDER OTHER DIVISIONS.
2. INSTALLING CONDUIT AND WIRING AS REQUIRED FOR SUCH EQUIPMENT.

M. INSTALLING AND CONNECTING ELECTRICALLY OPERATED EQUIPMENT, CABINETS, STARTERS, CONTROLS AND RELATED ITEMS FURNISHED UNDER OTHER DIVISIONS OR FURNISHED UNDER THIS DIVISION. INSTALLING CONDUIT AND WIRING AS REQUIRED FOR SUCH EQUIPMENT. COMPLYING WITH THE APPLICABLE PROVISIONS OF THE GENERAL CONDITIONS, SUPPLEMENTARY CONDITIONS, SPECIAL STATE CONDITIONS AND OTHER PROVISIONS OF THE CONTRACT DOCUMENTS THAT APPLY TO THE WORK INCLUDED IN DIVISION 26.

1.02 COORDINATION WITH UTILITY COMPANY

A. THE PUBLIC SERVICE COMPANY IS: GREEN MOUNTAIN POWER (GMP)

B. UTILITY BACK CHARGES WILL BE PAID BY OWNER.

C. WORK UNDER THIS SECTION SHALL BE CLOSELY COORDINATED WITH RELEVANT WORK OF THE LOCAL UTILITY COMPANY AND SHALL BE IN ACCORDANCE WITH REQUIREMENTS SET FORTH HEREBY.

D. SUBMIT DRAWINGS AND SPECIFICATIONS INDICATING WORK TO BE ACCOMPLISHED AND OBTAIN APPROVAL FROM THE LOCAL UTILITY COMPANY.

1.03 NOT INCLUDED

A. DIGGING, BACKFILLING, BLASTING, PUMPING, SHORING, CONCRETE AND WORK FURNISHED BY OTHER TRADES.

B. WORK SPECIFICALLY INDICATED TO BE DONE BY OWNER OR OTHERS.

1.04 REFERENCE STANDARDS

A. ELECTRICAL WORK SHALL CONFORM TO ALL REQUIREMENTS OF:

1. NATIONAL ELECTRIC CODE NEC
2. STATE BUILDING CODES
3. LOCAL ORDINANCES AND REGULATIONS.
4. NFPA FIRE CODES, CURRENT EDITION.
5. UNDERWRITERS' LABORATORIES STANDARDS.
6. LOCAL UTILITY COMPANY REQUIREMENTS.

B. IT SHALL BE UNDERSTOOD THAT ALL CODES AND STANDARDS MENTIONED SHALL BE THOSE IN FORCE AT THE TIME THE CONTRACT IS SIGNED. IF ANY CODES OR STANDARDS ARE CHANGED DURING THE CONSTRUCTION PERIOD, THESE SPECIFICATIONS MAY BE CHANGED BY MUTUAL AGREEMENT BETWEEN THE ENGINEER AND CONTRACTOR.

1.05 QUALITY ASSURANCE

A. CODES AND STANDARDS

1. COMPLY WITH NATIONAL ELECTRICAL CODE REQUIREMENTS FOR ELECTRICAL MATERIALS AND INSTALLATIONS.
2. KEEP COPY OF NATIONAL ELECTRICAL CODE IN FIELD OFFICE FOR DURATION OF PROJECT.
3. IN EACH CASE, CODES ARE MINIMUM REQUIREMENTS.

B. THE CONTRACTOR SHALL SUBMIT PROOF THAT THE ITEMS WHICH HE PROPOSES TO FURNISH UNDER THIS SPECIFICATION CONFORM TO THE STANDARDS OF UNDERWRITERS LABORATORIES, INC. (UL), FACTORY MUTUAL ENGINEERING CORP. (FM) OR WARNOCK HERSEY INC. (WH). THE LABELS OF THESE THREE ORGANIZATIONS SHALL BE ACCEPTED AS EVIDENCE OF COMPLIANCE. IF THE CONTRACTOR IS COMPLETELY FAMILIAR WITH THE NATIONALLY RECOGNIZED TESTING AGENCY, ADEQUATELY EQUIPPED AND COMPETENT TO PERFORM SUCH SERVICES, THAT THE ITEM HAS BEEN TESTED AND COMPLIED WITH THE STANDARDS INCLUDING METHODS OF TEST, OR THE TESTING ORGANIZATION(S).

C. QUALIFICATIONS OF INSTALLERS:

1. FOR THE ACTUAL FABRICATION, INSTALLATION AND TESTING OF THE WORK OF THIS SECTION USE ONLY THOROUGHLY TRAINED AND EXPERIENCED PERSONNEL WHO ARE COMPLETELY FAMILIAR WITH THE REQUIREMENTS FOR THIS WORK AND WITH THE INSTALLATION RECOMMENDATIONS OF THE MANUFACTURERS OF THE SPECIFIED ITEMS. CONTRACTOR SHALL BE ONE THAT IS REGULARLY ENGAGED IN THIS TYPE OF WORK.
2. IN THE ACCEPTANCE OR REJECTION OF THE INSTALLED ELECTRICAL SYSTEM, NO ALLOWANCE WILL BE MADE FOR LACK OF SKILL ON

THE PART OF INSTALLERS.

THE CONTRACTOR SHALL NOT BE RELIEVED FROM COMPLYING WITH ANY OF THE REQUIREMENTS OF THE SPECIFICATIONS OR DRAWINGS WHICH MAY BE IN EXCESS OF AND NOT CONTRARY TO THE REQUIREMENTS OF THE ABOVE MENTIONED RULES.

D. OBSERVATION CERTIFICATES:

1. DELIVER TO THE ENGINEER TWO (2) COPIES OF THE ELECTRICAL OBSERVER'S CERTIFICATE OF APPROVAL SHOWING ACCEPTABILITY OF THE SYSTEM MATERIALS BEFORE, DURING AND AFTER INSTALLATION AND TO PROTECT THE INSTALLED WORK AND MATERIALS OF ALL OTHER TRADES.
2. DELIVER TO THE ENGINEER TWO (2) COPIES OF ANY OTHER CERTIFICATES OF APPROVAL.

E. PRODUCT DELIVERY, STORAGE AND HANDLING

- A. PROTECTION: USE ALL MEANS NECESSARY TO PROTECT ELECTRICAL SYSTEM MATERIALS BEFORE, DURING AND AFTER INSTALLATION AND TO PROTECT THE INSTALLED WORK AND MATERIALS OF ALL OTHER TRADES.
- B. REPLACEMENTS: IN THE EVENT OF DAMAGE, IMMEDIATELY MAKE ALL REPAIRS AND REPLACEMENTS NECESSARY TO THE ACCEPTANCE OF THE ENGINEER AND AT NO ADDITIONAL COST TO THE OWNER, IF ANY. ANY REPLACEMENTS MUST BE DONE IN THE MOST EFFICIENT MANNER. IT SHALL BE THOROUGHLY DRIED OUT AND PUT THROUGH SUCH SPECIAL TESTS AS DIRECTED BY THE ENGINEER AT THE COST AND EXPENSE OF THE CONTRACTOR, OR SHALL BE REPLACED BY THE CONTRACTOR AT HIS OWNERS RISK.
- C. PROTECT THE WORK OF OTHER TRADES. RESTORE ANY DAMAGE CAUSED TO OTHER TRADES TO THE CONDITION EXISTING PRIOR TO DAMAGE AT NO ADDITIONAL COST TO THE OWNER.
- D. INVESTIGATE EACH SPACE IN THE BUILDING THROUGH WHICH EQUIPMENT MUST PASS TO THE EQUIPMENT LOCATION, IF NECESSARY, THE MANUFACTURER SHALL BE REQUIRED TO SHIP HIS MATERIAL IN SECTIONS SIZED TO PERMIT PASSING THROUGH SUCH RESTRICTED AREAS IN THE BUILDING.

F. PROJECT CONDITIONS

A. PROJECT DESCRIPTION:

1. THE PROJECT IS TO PROVIDE ALL ELECTRICAL EQUIPMENT NECESSARY TO PROVIDE A COMPLETE AND WORKING SYSTEM. PROVIDE ALL LABOR, MATERIALS, EQUIPMENT, APPLIANCES AND ACCESSORIES AND PERFORM ALL WORK NECESSARY TO THE COMPLETE EXECUTION OF THE ELECTRICAL WORK AS SHOWN ON THE DRAWINGS, REQUIRED BY THE SPECIFICATIONS AND WORK NOT SPECIFICALLY SHOWN OR SPECIFIED, YET REQUIRED TO INSURE PROPER AND COMPLETE OPERATION OF ALL SYSTEMS AND TO SATISFY THE DESIGN INTENT INHERENT IN THE WORK AND TO COMPLY WITH ALL APPLICABLE CODES AND REGULATIONS.
2. ALL MATERIAL REMOVED INCLUDING CONDUIT, WIRE AND RELATED ELECTRICAL EQUIPMENT IS TO BE DISPOSED OF BY THE CONTRACTOR IN A MANNER THAT COMPLIES WITH ALL RULES AND REGULATIONS APPLICABLE IN THE STATE OF VERMONT.

B. EXISTING CONDITIONS:

1. PRIOR TO ALL WORK OF THIS SECTION, CAREFULLY OBSERVE THE INSTALLED WORK OF ALL OTHER TRADES AND VERIFY THAT ALL SUCH WORK IS COMPLETE TO THE POINT WHERE THIS INSTALLATION MAY PROPERLY COMMENCE.
2. VERIFY THAT THE ELECTRICAL INSTALLATION MAY BE MADE IN COMPLETE ACCORDANCE WITH ALL PERTINENT CODES AND REGULATIONS AND THE DESIGN. IN THE EVENT OF A DISCREPANCY, IMMEDIATELY NOTIFY THE ENGINEER. DO NOT PROCEED WITH INSTALLATION IN AREAS OF DISCREPANCY UNTIL ALL SUCH DISCREPANCIES HAVE BEEN FULLY RESOLVED.
3. VERIFY SIZE AND RATING OF ELECTRICAL AND OTHER ELECTRICALLY OPERATED DEVICES SUPPLIED BY OTHERS.

C. COORDINATION:

1. COORDINATE THE INSTALLATION OF ELECTRICAL ITEMS WITH THE SCHEDULES FOR WORK OF OTHER TRADES TO PREVENT ANY UNNECESSARY DELAYS IN THE PROJECT.
2. ANY CHANGES SHALL BE DONE AT THE CONTRACTOR'S EXPENSE.
3. WHERE ELECTRICAL ITEMS ARE SHOWN IN CONFLICT WITH LOCATIONS OF STRUCTURAL MEMBERS AND MECHANICAL OR OTHER EQUIPMENT, FURNISH AND INSTALL ALL REQUIRED SUPPORTS AND WIRING TO CLEAR THE OBSTACLE.
4. IF ANY WORK INSTALLED CONTRARY TO OR WITHOUT ACCEPTANCE BY THE ENGINEER SHALL BE SUBJECT TO CHANGE AS DIRECTED BY THE ENGINEER, AND NO EXTRA COMPENSATION WILL BE ALLOWED THE CONTRACTOR FOR MAKING THESE CHANGES.

D. ACCURACY OF DATA:

1. THE DRAWINGS ARE DIAGRAMMATIC AND FUNCTIONAL ONLY, AND ARE NOT INTENDED TO SHOW EXACT CIRCUIT LAYOUTS, NUMBER OF FITTINGS, OR OTHER INSTALLATION DETAILS.
2. LOCATIONS ARE APPROXIMATE ONLY AND FIELD MEASUREMENTS ARE REQUIRED. WHERE DISCREPANCIES OR CONFLICTS OCCUR, CONSULT WITH ENGINEER BEFORE INSTALLATION.

G. PART PRODUCTS

A. MATERIALS

- A. MATERIALS AND EQUIPMENT SHALL BE LISTED BY UNDERWRITERS' LABORATORIES, OR OTHER OSHA ACCEPTED TESTING LABORATORY, AND SHALL BE CAPABLE OF BEING DEMONSTRATED THAT NO ITEM CAN BE FOR A SPECIFIC ITEM OR CLASS OF EQUIPMENT. ELECTRICAL EQUIPMENT SHALL BE HEAVY DUTY INDUSTRIAL GRADE OR FEDERAL SPECIFICATION GRADE OR BETTER. RESIDENTIAL OR COMMERCIAL GRADE PRODUCTS WILL NOT BE ACCEPTED. ALL OTHER MATERIALS, NOT SPECIFICALLY DESCRIBED BUT REQUIRED FOR A COMPLETE AND OPERABLE ELECTRICAL INSTALLATION, SHALL BE NEW, FIRST QUALITY OF THEIR RESPECTIVE KINDS, SPECIFICATION GRADE OR BETTER, AND AS SELECTED BY THE ENGINEER. CLEAR THE EXISTING WORK AND MAKE FINAL CONNECTIONS OF ELECTRICAL TO ALL EQUIPMENT FURNISHED UNDER OTHER SECTIONS. CONNECTIONS SHALL INCLUDE NECESSARY DISCONNECT SWITCHES, ETC. CONTRACTOR SHALL OBTAIN ACCEPTANCE ROUGH IN WORK DONE WITHOUT ACCEPTED DRAWINGS SHALL BE RELOCATED AT CONTRACTOR'S EXPENSE
- B. ALL CONTROL PANELS, WHETHER FABRICATED BY CONTRACTOR OR FURNISHED AS PART OF A MANUFACTURED EQUIPMENT ASSEMBLY, SHALL BE COMPLETED TO THE MAXIMUM EXTENT POSSIBLE BY THE ENGINEER AND COMPONENTS THAT HAVE BEEN TESTED AND LABELED BY UL, ETC, FM, OR OTHER OSHA ACCEPTED INDEPENDENT TESTING LABORATORY. ALL CONTROL PANELS SHALL BE UL LISTED AS A COMPLETE ASSEMBLY OR AS A PART OF EVALUATED PRODUCT. THE CONTRACTOR SHALL BEAR ALL COSTS RELATED TO THE UL FIELD EVALUATION, PANEL MODIFICATIONS AND FOLLOW-UP EVALUATIONS. CONTROL PANELS FAILING TO MEET UL LISTING STANDARDS SHALL BE REMOVED AND REPLACED BY LISTED EQUIPMENT AT NO COST TO THE OWNER.
- C. ALL OTHER MATERIALS, NOT SPECIFICALLY DESCRIBED BUT REQUIRED FOR A COMPLETE AND OPERABLE ELECTRICAL INSTALLATION, SHALL BE NEW, FIRST QUALITY OF THEIR RESPECTIVE KINDS, AND AS SELECTED BY THE ENGINEER. CLEAR THE EXISTING WORK AND MAKE FINAL CONNECTIONS OF ELECTRICAL TO ALL EQUIPMENT FURNISHED UNDER OTHER SECTIONS. CONNECTIONS SHALL INCLUDE NECESSARY DISCONNECT SWITCHES, ETC. CONTRACTOR SHALL OBTAIN ACCEPTANCE ROUGH IN WORK DONE WITHOUT ACCEPTED DRAWINGS SHALL BE RELOCATED AT CONTRACTOR'S EXPENSE
- D. LOCATE ALL EQUIPMENT WHICH MUST BE SERVICED, OPERATED, OR MAINTAINED IN FULL ACCESSIBLE POSITIONS. EQUIPMENT SHALL INCLUDE BUT NOT BE LIMITED TO MOTORS, CONTROLLERS, SWITCHGEAR AND PANELS.

H. INTERCHANGEABILITY

- A. IN ALL DESIGN AND PURCHASING, INTERCHANGEABILITY OF ITEMS OF EQUIPMENT, SUBASSEMBLIES, PARTS, AND OTHER ITEMS IS ESSENTIAL. FOR EACH ITEM, THE MANUFACTURER, TYPE, MODEL AND DIMENSIONS SHALL BE OF THE SAME MANUFACTURER, TYPE, MODEL AND DIMENSIONS.
- B. THE ENGINEER RESERVES THE RIGHT TO REJECT ANY SUBMITTAL WHICH CONTAINS EQUIPMENT FROM VARIOUS MANUFACTURERS IF SUITABLE EQUIPMENT CAN BE SECURED FROM FEWER MANUFACTURERS AND TO REQUIRE THAT SOURCE OF MATERIALS BE UNIFIED TO THE MAXIMUM EXTENT POSSIBLE.

1. VERIFY THE SUFFICIENCY AND THE SIZE OF SPACES FOR THE PROPER INSTALLATION OF THE WORK, COORDINATE AND COOPERATE WITH ALL OTHER TRADES WHOSE WORK IS WITHIN THE SAME SPACE. COORDINATE CLEARANCE REQUIREMENTS AMONG VARIOUS PIECES OF EQUIPMENT THAT WILL BE INSTALLED IN CLOSE PROXIMITY WITH ONE ANOTHER TO ELIMINATE EQUIPMENT CONFLICTS AND INTERFERENCE.

2. LOCATE ALL EQUIPMENT WHICH MUST BE SERVICED, OPERATED, OR MAINTAINED IN FULL ACCESSIBLE POSITIONS. EQUIPMENT SHALL INCLUDE BUT NOT BE LIMITED TO MOTORS, CONTROLLERS, SWITCHGEAR AND PANELS. COORDINATE AND COOPERATE WITH ALL OTHER TRADES WHOSE WORK IS WITHIN THE SAME SPACE. I.N.E.C. CODE CLEARANCES SHALL BE MAINTAINED AT ALL TIMES AND SHALL BE CONSIDERED THE MINIMUM CLEARANCES ALLOWED.

04 CONNECTIONS TO EQUIPMENT AND FIXTURES

ROUGH-IN AND MAKE FINAL CONNECTIONS OF ELECTRICAL TO ALL EQUIPMENT. FURNISH AND UNDO OTHER SECTIONS. CONNECTIONS SHALL INCLUDE NECESSARY DISCONNECT SWITCHES, ETC. CONTRACTOR SHALL OBTAIN ACCEPTED ROUGH-IN DRAWINGS FOR EQUIPMENT BEFORE STARTING WORK. ROUGH-IN WORK DONE WITHOUT ACCEPTED DRAWINGS SHALL BE RELOCATED AT CONTRACTOR'S EXPENSE.

05 PAINTING AND CLEANING

A. PAINTING SHALL BE UNDER THE SECTION 09090 EXCEPT AS STATED BELOW.

B. METAL SURFACES (CONDUIT HANGERS, SUPPORTS, ETC.) EXPOSED TO OUTDOORS SHALL BE GIVEN TWO (2) COATS OF RUST INHIBITING PAINT BY THE INSTALLING CONTRACTOR PER MANUFACTURER'S INSTRUCTIONS. CONDUIT, STEEL, BOLTS, ETC. INSTALLED IN EARTH OR BELOW VAPOR BARRIER SHALL BE GIVEN TWO (2) COATS OF ZINC RICH COMPOUND. MATERIAL EMBEDDED IN CONCRETE NEED NOT BE PAINTED. CONDUIT PROTRUDING THROUGH CONCRETE FLOORS SHALL BE PLASTIC AT THE POINT OF BREACH.

06 ELECTRICAL EQUIPMENT MANUFACTURERS

A. ACCEPTABLE MANUFACTURERS:

1. EATON CORPORATION; CUTLER-HAMMER PRODUCTS.
2. GENERAL ELECTRIC CO.; ELECTRICAL DISTRIBUTION & CONTROL DIVISION.
3. SIEMENS ENERGY & AUTOMATION, INC.
4. SQUARE D/GEORGE A. SULLIVAN CO.

B. SUBSTITUTIONS: ITEMS OF SAME FUNCTION AND PERFORMANCE ARE ACCEPTABLE IN COMPLIANCE WITH THE GENERAL REQUIREMENTS. MANUFACTURER'S CATALOG NUMBERS ARE USED TO DEFINE QUALITY AND PERFORMANCE AND ARE NOT INTENDED TO PROHIBIT USE OF COMPARABLE PRODUCTS BY OTHER MANUFACTURERS.

07 BUILDING WIRING AND IT CABLEING

A. BRANCH CIRCUIT WIRING IN CONDUIT SHALL BE TYPE THHN-THWN, 600V COPPER, UL LISTED. MINIMUM SIZE: #12 AWG WITH GROUND. WIRING LARGER THAN #8 SHALL BE STRANDED. ALL WIRING SHALL BE IN CONDUIT (EMT) OR TYPE MC AS ACCEPTED BY THE ENGINEER.

B. CONDUIT SHALL BE EMT. MOTOR CONNECTIONS SHALL BE MADE WITH EMT. CONDUIT SHALL BE USED FOR ALL CONDUCTORS.

C. CONDUIT UNDERGROUND SHALL BE SCHEDULE 40 PVC, 1/2" MINIMUM.

D. SPLICES FOR #10 AWG AND SMALLER WIRE SHALL BE WIRE NUT TYPE AND SOLDERLESS LUGS FOR #8 AWG AND LARGER.

E. COLOR-CODING FOR PHASE AND VOLTAGE LEVEL IDENTIFICATION, 600 V AND LESS: USE THE COLORS LISTED BELOW FOR UNGROUNDED SERVICE, FEEDER AND BRANCH CIRCUIT CONDUCTORS.

1. COLOR SHALL BE FACTORY APPLIED.
2. COLORS FOR 208Y/120-V AND 240/120 CIRCUITS:
 - a. PHASE A: BLACK.
 - b. PHASE B: RED.
 - c. PHASE C: BLUE.
 - d. NEUTRAL: WHITE
 - e. SWITCH LEG - OTHER THAN PHASE WIRE COLOR
 - f. GROUND - GREEN, IF INSULATED
3. COLORS FOR 480V CIRCUITS:
 - a. CONDUCTOR 1: ONE/BLACK.
 - b. CONDUCTOR 1: TWO/RED.
 - c. CONDUCTOR 1: THREE/BLUE.
 - d. CONDUCTOR 1: FOUR/ORANGE.
 - e. GROUND - GREEN, IF INSULATED

F. PULL AND JUNCTION AND BOXES:

1. PULLBOXES AND JUNCTION BOXES: METAL OR NONMETALLIC TYPE CONSTRUCTION. CONSTRUCTION TO NATIONAL ELECTRICAL CODE, WITH SCREW-ON OR HINGED COVER, SIZE AND LOCATION BOXES AS REQUIRED.
2. ENCLOSURE TYPES SHALL BE USED AS FOLLOWS:
 - a. NEMA 1 - INTERIOR LOCATIONS, DRY.
 - b. NEMA 12 - INTERIOR LOCATIONS, SUBJECT TO OIL, SEEPAGE OR DUST, MAY SUBSTITUTED FOR NEMA 1.
 - c. NEMA 3R - EXTERIOR WET LOCATIONS ON OUTDOOR STRUCTURES WHERE MOISTURE IS PRESENT, ENCLOSURES ARE TO BE CONSTRUCTED OF STAINLESS STEEL OR PAINTED ALUMINUM.

08 DISCONNECT SWITCHES

PROVIDE HEAVY-DUTY TYPE, FUSED OR UNFUSED AS REQUIRED. FUSES SHALL BE TYPE TIME DELAY RK-1 OR EQUIVALENT, UNLESS OTHERWISE NOTED. PROVIDE GROUNDING AND BONDING EQUIPMENT WHERE NOT FURNISHED WITH EQUIPMENT OR BY DRAWING 23, FULLY COORDINATE BETWEEN TRADES.

09 FUSIBLE AND NONFUSIBLE SWITCHES

FUSIBLE SWITCH, 600 A AND SMALLER: NEMA KS 1, TYPE HD, WITH CLIPS OR CLAMP MOUNTING. HANDLE SPECIFIED FUSES, LOCKABLE HANDLE WITH CAPABILITY TO ACCEPT TWO PADLOCKS, AND INTERLOCKED WITH COVER IN CLOSED POSITION.

NONFUSIBLE SWITCH, 600 A AND SMALLER: NEMA KS 1, TYPE HD, LOCKABLE HANDLE WITH CAPABILITY TO ACCEPT TWO PADLOCKS, AND INTERLOCKED WITH COVER IN CLOSED POSITION.

A. ACCESSORIES:

1. EQUIPMENT GROUND KIT: INTERNALLY MOUNTED AND LABELED FOR COPPER AND ALUMINUM GROUND CONDUCTORS.
2. NEUTRAL KIT: INTERNALLY MOUNTED; INSULATED, CAPABLE OF BEING GROUNDING AND LABELED FOR COPPER AND ALUMINUM NEUTRAL CONDUCTORS.
3. AUXILIARY CONTACT KIT: AUXILIARY SET OF CONTACTS ARRANGED TO OPEN BEFORE SWITCH BLADES OPEN.

10 MOLDED-CASE CIRCUIT BREAKERS AND SWITCHES

A. MOLDED-CASE CIRCUIT BREAKER: NEMA TYPE WITH INTERRUPTING CAPACITY TO MEET AVAILABLE FAULT CURRENTS:

1. THERMAL-MAGNETIC CIRCUIT BREAKERS: INVERSE TIME-CURRENT ELEMENT FOR LOW-LEVEL OVERLOADS AND INSTANTANEOUS MAGNETIC TRIP ELEMENT FOR SHORT CIRCUITS. ADJUSTABLE MAGNETIC TRIP SETTING FOR CIRCUIT-BREAKER FRAME SIZES 250 A AND LARGER.
2. ADJUSTABLE INSTANTANEOUS-TRIP CIRCUIT BREAKERS: MAGNETIC TRIP ELEMENT WITH FRONT-MOUNTED, FIELD-ADJUSTABLE TRIP RATING.
3. CURRENT-LIMITING CIRCUIT BREAKERS: FRAME SIZES 400 A AND SMALLER AND LET-THROUGH RATINGS LESS THAN NEMA FU 1, RKF-5.
4. GFCI CIRCUIT BREAKERS: SINGLE- AND TWO-POLE CONFIGURATIONS WITH 5-mA TRIP SENSITIVITY.

B. MOLDED-CASE CIRCUIT-BREAKER FEATURES AND ACCESSORIES:

1. STANDARD FRAME SIZES, TRIP RATINGS, AND NUMBER OF POLES.
2. LUGS: MECHANICAL STYLE WITH COMPRESSION LUG KITS SUITABLE FOR NUMBER, SIZE, TRIP RATINGS, AND CONDUCTOR MATERIAL.

3. APPLICATION LISTING: TYPE SWD FOR SWITCHING FLOUORESCENT LIGHTING LOADS; TYPE HACR FOR HEATING, AIR-CONDITIONING, AND REFRIGERATING EQUIPMENT.

11 ENCLOSURES

NEMA AB 1 AND NEMA KS 1 TO MEET ENVIRONMENTAL CONDITIONS OF INSTALLED LOCATION.

1. OUTDOOR LOCATIONS: NEMA 250, TYPE 3R.
2. CHEMICAL: NEMA 250, TYPE 4X, STAINLESS STEEL OR NON-METALLIC, AND ACCESSORIES AS RECOMMENDED BY THE MANUFACTURER.
3. OTHER WET OR DAMP INDOOR LOCATIONS: NEMA 250, TYPE 4.

12 GROUNDING

WORK INCLUDED:

1. FURNISHING POWER SYSTEM GROUNDING.
2. INSTALLATION.
3. PROVIDE AND INSTALL EACH ELECTRICAL GROUNDING SYSTEM WITH ASSEMBLY OF MATERIALS REQUIRED FOR COMPLETE INSTALLATION INCLUDING WIRES/CABLES, CONNECTORS, LUGS, CLAMPS, GROUND RODS, BONDING JUMPERS AND ACCESSORIES.
4. PROVIDE AND INSTALL ELECTRICAL CONNECTORS, LUGS, CLAMPS, BONDING JUMPERS AND ACCESSORIES AS RECOMMENDED BY THE RESPECTIVE MANUFACTURER FOR THE PARTICULAR APPLICATION, UNLESS OTHERWISE INDICATED.

GROUNDING AND BONDING EXECUTION:

1. INSTALL BONDING JUMPER FOR FLEXIBLE METAL CONDUIT UNLESS FITTINGS ARE ACCEPTED FOR GROUNDING OR OTHERWISE COMPLY WITH N.E.C.
 - a. SIZE JUMPER TO MATCH OVER-CURRENT DEVICE.
 - b. GREEN INSULATION.
 - c. CONNECT TO GROUNDING BUSHING AT EACH END.
2. ENSURE THAT ENTIRE ELECTRICAL SYSTEM IS ELECTRICALLY CONTINUOUS AND EFFECTIVELY GROUNDING, INCLUDING ALL ELECTRICAL EQUIPMENT AND MOTORS.

13 SUPPORTING DEVICES AND LABELS

GALVANIZED CONDUIT CLAMPS. DO NOT USE PERFORATED PIPE STRAPS.

ANCHOR METHODS:

1. SOLID MASONRY: ACCEPTED STAINLESS STEEL EXPANSION ANCHORS OR PRESET INSERTS. RAWL OR DIAMOND MANUFACTURER OR EQUAL.
2. METAL SURFACES: GALVANIZED MACHINE SCREWS, BOLTS, OR WELDED STUDS.
3. CONCRETE SURFACES: SELF-DRILLING STAINLESS STEEL ANCHORS OR POWER-DRIVEN STUDS. STAR, DIAMOND OR RAWL MANUFACTURER OR EQUAL.
4. COMPLY WITH NFPA 70 AND 29 CFR 1910.145. SELF-ADHESIVE WARNING LABELS: FACTORY PRINTED, MULTICOLOR.
5. SELF-ADHESIVE, ENGRAVED, LAMINATED ACRYLIC OR MELAMINE LABEL. ADHESIVE BACKED, WITH WHITE LETTERS ON A DARK-GRAY BACKGROUND. MINIMUM LETTER HEIGHT SHALL BE 3/8 INCH.

5. EQUIPMENT IDENTIFICATION LABELS

- a. ADHESIVE FILM LABEL WITH CLEAR PROTECTIVE OVERLAY: MACHINE PRINTED IN BLACK, BY THERMAL TRANSFER OR EQUIVALENT PROCESS. MINIMUM LETTER HEIGHT SHALL BE 3/8 INCH. OVERLAY SHALL PROVIDE A WEATHERPROOF AND ULTRAVIOLET-RESISTANT SEAL FOR LABEL.
- b. SELF-ADHESIVE, ENGRAVED, LAMINATED ACRYLIC OR MELAMINE LABEL. ADHESIVE BACKED, WITH WHITE LETTERS ON A DARK-GRAY BACKGROUND. MINIMUM LETTER HEIGHT SHALL BE 3/8 INCH.

6. AUXILIARY ELECTRICAL SYSTEMS INCLUDING EQUIPMENT, CONDUCTORS AND CABLE IDENTIFICATION: USE MARKER TAPE TO IDENTIFY FIELD-INSTALLED ALARM, CONTROL, SIGNAL, COMMUNICATIONS, VOICE, AND DATA WIRING CONNECTIONS.

- a. IDENTIFY CONDUCTORS, CABLES, AND TERMINALS IN ENCLOSURES AND AT JUNCTIONS, TERMINALS, AND CABLE PULL POINTS. IDENTIFY BY SYSTEM AND CIRCUIT DESIGNATION.
- b. USE SYSTEM OF DESIGNATIONS THAT IS UNIFORM AND CONSISTENT WITH SYSTEM USED BY MANUFACTURER FOR FACTORY-INSTALLED CONNECTIONS.
- c. WARNING LABELS FOR INDOOR CABINETS, BOXES, AND ENCLOSURES FOR POWER AND LIGHTING: COMPLY WITH 29 CFR 1910.145 AND APPLY SELF-ADHESIVE WARNING LABELS, BAKED-ENAMEL WARNING SIGNS, OR METAL-BACKED, BUTYRATE WARNING SIGNS. IDENTIFY SYSTEM VOLTAGE WITH BLACK LETTERS ON AN ORANGE BACKGROUND. APPLY TO EXTERIOR OF DOOR, COVER, OR OTHER ACCESS POINT.
- d. EQUIPMENT WITH MULTIPLE POWER OR CONTROL SOURCES: APPLY TO DOOR OR COVER OF EQUIPMENT INCLUDING, BUT NOT LIMITED TO, THE FOLLOWING: EQUIPMENT REQUIRING WORKSPACE CLEARANCE ACCORDING TO NFPA 70; UNLESS OTHERWISE INDICATED, APPLY TO DOOR OR COVER OF EQUIPMENT BUT NOT ON FLUSH PANELBOARDS AND SIMILAR EQUIPMENT IN FINISHED SPACES.

7. EQUIPMENT IDENTIFICATION LABELS: ON EACH UNIT OF EQUIPMENT, INSTALL A UNIQUE IDENTIFICATION LABEL THAT IS CONSISTENT WITH WIRING DIAGRAMS, SCHEDULES, AND OPERATION AND MAINTENANCE MANUAL. APPLY LABELS TO DISCONNECT SWITCHES AND PROTECTION EQUIPMENT, CENTRAL OR MASTER UNITS, CONTROL PANELS, CONTROL STATIONS, TERMINAL CABINETS, AND RACKS OF EACH SYSTEM.

8. SYSTEMS INCLUDE POWER, LIGHTING, CONTROL, COMMUNICATION, SIGNAL, MONITORING, AND ALARM SYSTEMS UNLESS EQUIPMENT IS PROVIDED WITH ITS OWN IDENTIFICATION. OUTDOOR EQUIPMENT: ENGRAVED, LAMINATED ACRYLIC OR MELAMINE LABEL, DRILLED FOR SCREW ATTACHMENT. THE FOLLOWING DEVICES SHALL BE LABELED: PANELBOARDS, ELECTRICAL CABINETS, ENCLOSURES, TRANSFORMERS, CONVERTERS, TRANSISTORS, DISCONNECT SWITCHES, CIRCUIT BREAKERS, POWER TRANSFER EQUIPMENT, AND CONTACTORS.

14 DEVICES AND OUTLET BOXES

OUTLET BOX CONSTRUCTION:

1. INTERIOR LOCATIONS: STEEL 4" SQUARE MINIMUM CONFORMING TO UL REQUIREMENTS.
2. EXTERIOR LOCATIONS: CAST METAL, DEEP TYPE.

SIZE BOXES PER NEC, MINIMUM 1-1/2 INCHES DEEP. USE GANG BOXES FOR MULTIPLE OUTLETS.

COVER PLATES:

1. PROVIDE OPENINGS AS REQUIRED.

DEVICES - NOTE: BRIDGE SPECIFICATION GRADE DEVICES 120V, 20A, UL LISTED, COLOR IVORY WITH MATCHING COVER PLATES.

1. RECEPTACLES, RECEPTACLES WITH INTEGRAL GFCI, AND ASSOCIATED DEVICE PLATES.
2. RECEPTACLES WITH INTEGRAL SURGE SUPPRESSION UNITS.
3. SNAP SWITCHES.
4. WALL-SWITCH OCCUPANCY SENSORS.
5. COMMUNICATIONS OUTLETS.
6. CEILING MOUNTED OCCUPANCY SENSORS.

SOURCE LIMITATIONS: OBTAIN EACH TYPE OF WIRING DEVICE AND ASSOCIATED WALL PLATE THROUGH ONE SOURCE FROM A SINGLE MANUFACTURER. INsofar AS THEY ARE AVAILABLE, OBTAIN ALL WIRING DEVICES AND ASSOCIATED WALL PLATES FROM A SINGLE MANUFACTURER AND ONE SOURCE.

ELECTRICAL COMPONENTS, DEVICES, AND ACCESSORIES: LISTED AND LABELED AS DEFINED IN NEC, ARTICLE 100, BY A TESTING AGENCY ACCEPTABLE TO AUTHORITIES HAVING JURISDICTION, AND MARKED FOR INTENDED USE.

MANUFACTURERS' NAMES: SHORTENED VERSIONS (SHOWN IN PARENTHESES):

1. COOPER WIRING DEVICES; A DIVISION OF COOPER INDUSTRIES, INC. (COOPER).
2. HUBBELL INCORPORATED; WIRING DEVICE-KELLOGG (HUBBELL).

3. LEVITON MFG. COMPANY INC. (LEVITON).

4. PASS & SEYMOUR/LEGRAND; WIRING DEVICES & ACCESSORIES (PASS & SEYMOUR).

CONVENIENCE RECEPTACLES, 125 V, 20 A; COMPLY WITH NEMA WD 1, NEMA WD 6 CONFIGURATION 5-20-15, AND UL 498.

a. COOPER; 5351 (SINGLE), 5352 (DUPEX).

2. HUBBELL; HBL3531 (SINGLE), CR5352 (DUPEX).

3. LEVITON; 5891 (SINGLE), 5352 (DUPEX).

4. PASS & SEYMOUR; 5381 (SINGLE), 5352 (DUPEX).

CORD AND PLUG DESCRIPTION: MATCH VOLTAGE AND CURRENT RATINGS AND NUMBER OF CONDUCTORS TO REQUIREMENTS OF EQUIPMENT BEING CONNECTED.

1. CORD: RUBBER-INSULATED, STRANDED-COPPER CONDUCTORS, WITH TYPE SOW-A JACKET; WITH GREEN-INSULATED GROUNDING CONDUCTOR AND EQUIPMENT-RATING AMPACITY PLUS A MINIMUM OF 30 PERCENT.

2. PLUG: NYLON BODY AND INTEGRAL CABLE-CLAMPING JAWS. MATCH CORD AND RECEPTACLE TYPE FOR CONNECTION.

SWITCHES, 120/277 V, 15 A:

3. PRODUCTS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE ONE OF THE FOLLOWING:

a. COOPER; 2221 (SINGLE POLE), 2222 (TWO POLE), 2223 (THREE WAY), 2224 (FOUR WAY).

b. HUBBELL; CS1221 (SINGLE POLE), CS1222 (TWO POLE), CS1223 (THREE WAY), CS1224 (FOUR WAY).

c. LEVITON; 1221-2 (SINGLE POLE), 1222-2 (TWO POLE), 1223-2 (THREE WAY), 1224-2 (FOUR WAY).

d. PASS & SEYMOUR; 20AC1 (SINGLE POLE), 20AC2 (TWO POLE), 20AC3 (THREE WAY), 20AC4 (FOUR WAY).

DEVICE WIRING

1. COMPLY WITH NECA 1, INCLUDING THE MOUNTING HEIGHTS LISTED IN THAT STANDARD, UNLESS OTHERWISE NOTED.

2. COORDINATION: OTHER TRADES MUST TAKE STEPS TO INSURE THAT DEVICES AND THEIR BOXES ARE PROTECTED. DO NOT PLACE WALL FINISH MATERIALS OVER DEVICE BOXES AND DO NOT CUT HOLES FOR BOXES WITH ROUTERS THAT ARE GUIDED BY RIDING AGAINST OUTSIDE OF THE BOXES.

3. KEEP OUTLET BOXES FREE OF PLASTER, DRYWALL JOINT COMPOUND, MORTAR, CEMENT, CONCRETE, DUST, PAINT, AND OTHER MATERIAL THAT MAY CONTAMINATE THE RACEWAY SYSTEM, CONDUCTORS, AND CABLES.

4. INSTALL DEVICE BOXES OF BRICK OR BLOCK WALLS SO THAT THE COVER PLATE DOES NOT CRACK A JOINT UNLESS THE JOINT IS TROWELED FLUSH WITH THE FACE OF THE WALL.

5. INSTALL WIRING DEVICES AFTER ALL WALL PREPARATION, INCLUDING PAINTING, IS COMPLETE.

6. CONDUCTORS AND DEVICE INSTALLATION:

a. DO NOT STRIP INSULATION FROM CONDUCTORS UNTIL JUST BEFORE THEY ARE SPLICED OR TERMINATED ON DEVICES.

b. STRIP INSULATION EVENLY AROUND THE CONDUCTOR USING TOOLS DESIGNED FOR THE PURPOSE, AVOID SCORING OR NICKING OF BOLD WIRE OR CUTTING STRANDS FROM STRANDED WIRE.

c. THE LENGTH OF FREE CONDUCTORS AT OUTLETS FOR DEVICES SHALL MEET PROVISIONS OF NEC, ARTICLE 300, WITHOUT PITCH.

7. REPLACE ALL DEVICES THAT HAVE BEEN IN TEMPORARY USE DURING CONSTRUCTION OR THAT SHOW SIGNS THAT THEY WERE INSTALLED BEFORE FINISHING OPERATIONS WERE COMPLETE.

a. KEEP EACH WIRING DEVICE IN ITS PACKAGE OR OTHERWISE PROTECTED UNTIL IT IS TIME TO CONNECT CONDUCTORS.

b. DO NOT REMOVE SURFACE PROTECTION, SUCH AS PLASTIC FILM AND SMUDGE COVERS, UNTIL THE LAST POSSIBLE MOMENT.

c. CONNECT DEVICES TO BRANCH CIRCUITS USING PIGTAILS THAT ARE NOT LESS THAN 6 INCHES (152 MM) IN LENGTH.

d. WHEN THERE IS A CHOICE, USE SIDE WIRING WITH BINDING-HEAD SCREW TERMINALS. WRAP SOLID CONDUCTOR TIGHTLY CLOCKWISE, 2/3 TO 3/4 OF THE WAY AROUND TERMINAL SCREW.

e. USE A TORQUE SCREWDRIVER WHEN A TORQUE IS RECOMMENDED OR REQUIRED BY THE MANUFACTURER.

f. WHEN CONDUCTORS LARGER THAN NO. 12 AWG ARE INSTALLED ON 15- OR 20-A CIRCUITS, SPLICE NO. 12 AWG PIGTAILS FOR DEVICE CONNECTIONS.

ART 3 EXECUTION

01 INSTALLATION

1. INSTALL ALL EQUIPMENT AND FIXTURES IN COMPLETE ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS AND ALL PERTINENT CODES AND REGULATIONS.

2. THOROUGHLY OBSERVE ALL ITEMS OF EQUIPMENT AND ANY ITEMS DENTED, SCRATCHED OR OTHERWISE DAMAGED IN ANY MANNER SHALL BE REPLACED OR REPAIRED AND PAINTED TO MATCH ORIGINAL FINISH.

3. ALL ITEMS TO BE REMOVED AND REFINISHED BE BROUGHT TO THE ATTENTION OF THE ARCHITECT FOR OBSERVATION AND APPROVAL.

4. UPON COMPLETION OF ALL INSTALLATION, LAMPING, AND TESTING, THOROUGHLY OBSERVE ALL EXPOSED PORTIONS OF THE ELECTRICAL INSTALLATION AND COMPLETELY REMOVE ALL EXPOSED LABELS, SOIL, MARKINGS AND FOREIGN MATERIAL.

02 CUTTING AND PATCHING

1. ALL CUTTING AND PATCHING SHALL AS BE DESCRIBED UNDER OTHER SECTIONS.

03 FLOOR AND WALL PENETRATIONS

1. PROVIDE, LOCATE AND SET ALL SLEEVES AND INSERTS AS REQUIRED FOR THIS WORK. PREPARE DIMENSIONED FLOOR AND WALL PENETRATION DRAWINGS, SHOWING THE SIZE AND LOCATION OF EACH PENETRATION ON EVERY FLOOR AND IN EVERY WALL WHICH IS TO ACCOMMODATE THIS WORK. THE PENETRATION DRAWINGS SHALL INCLUDE, BUT NOT BE LIMITED TO HANGERS, INSERTS, CONDUITS, RACEWAYS, AND CURBS.

2. DRAWINGS SHALL BE SUBMITTED TO THE ARCHITECT IN ADVANCE OF THE WORK TO BE DONE. IN ADVANCE THAT ADJUSTMENTS MAY BE MADE TO THE DRAWINGS TO REFLECT THE STEEL, STRUCTURAL, FRAMING AND OTHER RELATED WORK WITHOUT INTERRUPTION TO THE CONSTRUCTION SCHEDULE. ALL SLEEVES, COLLARS, HANGERS, INSERTS, ETC., SHALL BE SUBMITTED TO THE ARCHITECT FOR REVIEW PRIOR TO CONSTRUCTING FLOORS AND WALLS. EACH CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DRILLING AND AS ACCEPTED BY THE ARCHITECT.

3. WHERE CONDUIT MOTION DUE TO EXPANSION AND CONTRACTION WILL OCCUR, MONITOR SLEEVES SUFFICIENTLY LONGER TO PERMIT FREE MOVEMENT, CHECK FLOOR AND WALL CONSTRUCTION FINISH TO DETERMINE PROPER LENGTH OF SLEEVES FOR VARIOUS LOCATIONS, MAKE ACTUAL LENGTH TO SUIT THE FOLLOWING:

1. TERMINATE SLEEVES FLUSH WITH WALLS, PARTITIONS, AND CEILING.

2. IN AREAS WHERE CONDUIT IS CONCEALED, AS IN CHASES, TERMINATE SLEEVES FLUSH WITH FLOOR.

3. IN ALL AREAS WHERE CONDUIT IS EXPOSED, EXTEND SLEEVES 1/4" ABOVE FINISHED FLOOR, EXCEPT IN ROOMS HAVING FLOOR DRAINS, WHERE SLEEVES SHALL BE EXTENDED 3/4" ABOVE FLOOR.

4. SLEEVES SHALL BE CONSTRUCTED OF 22-GAUGE GALVANIZED SHEET STEEL WITH LOCK SEAM JOINTS FOR ALL SLEEVES SET IN CONCRETE FLOOR SLABS TERMINATING FLUSH WITH THE FLOOR. ALL OTHER SLEEVES SHALL BE CONSTRUCTED OF GALVANIZED STEEL PIPE. FASTEN SLEEVES SECURELY TO FLOORS, WALLS, ETC., SO THAT THEY WILL NOT BECOME DISPLACED WHEN CONCRETE IS POURED OR WHEN OTHER CONSTRUCTION IS BUILT AROUND THEM. TAKE PRECAUTIONS TO PREVENT CONCRETE, PLASTER, OR OTHER MATERIALS BEING FORCED INTO THE SPACE BETWEEN PIPE AND SLEEVE DURING CONSTRUCTION.

WHERE CONDUITS PASS THROUGH FLOORS OR RATED WALLS, THE OPENINGS AROUND THE CONDUITS SHALL BE SEALED WITH 3M, HILTI OR ACCEPTED FIRE SEALING COMPOUND PROVIDED BY AN ACCEPTED MANUFACTURER. CONDUIT FLOOR PENETRATIONS WITHIN RATED CHASES SHALL BE SEALED WITH SMOKE BARRIER SEALANTS. THE 3M, HILTI OR ACCEPTED MANUFACTURER'S TYPE SEALANT USED SHALL BE ACCEPTED BY THE LOCAL AUTHORITIES HAVING JURISDICTION AND CARRY U.L. LISTING FOR RATING OF ASSEMBLY. ALL PRODUCTS SHALL BE LISTED FOR A TWO HOUR RATING UNLESS NOTED OTHERWISE.

ALL CONDUITS AND RELATED BRANCH CIRCUITS IN ANY EXTERIOR LOCATIONS IN THE FACILITY SHALL BE SEALED WATERTIGHT TO PREVENT WATER AND CONDENSATION FROM ENTERING THE BUILDING OR FIXTURES, BOXES, RECEPTACLES AND RELATED DEVICES.

04 ELECTRICAL CONNECTIONS TO EQUIPMENT AND SYSTEMS

EQUIPMENT WIRING SHALL BE AS FOLLOWS:

1. ALL WIRING SHALL BE PROVIDED UNDER DIVISION 26. ALL ASSOCIATED CONTROL WIRING FOR EQUIPMENT DESCRIBED UNDER DIVISION 23 AND OTHER CONTROL WIRING REQUIRED TO BE PROVIDED BY DIVISION 23.
2. ALL CONTROL ITEMS CONNECTED SHALL BE MARKED PLAINLY BY MACHINE-MADE NAMEPLATE ON THE EQUIPMENT THAT IS CONTROLLED, TO THE ACCEPTANCE OF THE OWNER.
3. THE HORSEPOWER RATING OF ALL STARTERS SHALL BE CHECKED AGAINST ACTUAL MOTOR TO BE CONTROLLED, BEFORE INSTALLATION, AND CORRECT SIZE OVERLOAD ELEMENTS SHALL BE PROVIDED IN ALL STARTERS BASED ON NAMEPLATE AND MANUFACTURER'S RECOMMENDATION.
4. GENERAL CLEARANCE REQUIREMENTS: PROVIDE CLEARANCE SPACES BETWEEN AND AROUND PROCESS, MECHANICAL AND ELECTRICAL EQUIPMENT FOR OPERATION, MAINTENANCE AND REPLACEMENT OF EQUIPMENT. MINIMUM CLEARANCES FOR EACH ITEM OR PIECE OF EQUIPMENT SHALL BE AS STATED IN THE MANUFACTURER'S PRINTED RECOMMENDATIONS OR AS SHOWN ON THE MANUFACTURER'S PRINTED DRAWINGS. COORDINATE CLEARANCE REQUIREMENTS AMONG VARIOUS PIECES OF EQUIPMENT THAT WILL BE INSTALLED IN CLOSE PROXIMITY WITH ONE ANOTHER TO ELIMINATE EQUIPMENT CONFLICTS AND INTERFERENCE. PREPARE AND SUBMIT SHOP DRAWINGS IF REQUESTED BY THE ARCHITECT SHOWING PROPOSED EQUIPMENT LAYOUTS AND CLEARANCES. N.E.C. CODE CLEARANCES SHALL BE MAINTAINED AT ALL TIMES AND SHALL BE CONSIDERED THE MINIMUM CLEARANCES ALLOWED.

06 DEBRIS

ALL DEBRIS SHALL BE REMOVED AS IT ACCUMULATES AND SHALL NOT BE STORED OR PERMITTED TO ACCUMULATE ON-SITE. REMOVE ALL DEBRIS AT THE END OF EACH WORKING DAY.

07 ENERGIZING ELECTRICAL SYSTEM


















PRIOR TO ENERGIZING MAIN ELECTRICAL SYSTEM PERFORM THE FOLLOWING:









1. ENSURE SUPPLY AUTHORITY VOLTAGE AND PHASE ROTATION. VERIFY ALL INDEPENDENT TESTING AS SPECIFIED HAS BEEN COMPLETED AND DEFICIENCIES HAVE BEEN CORRECTED.
 - a. MEGGER ALL FEEDERS AND RECORD RESULTS ON ACCEPTED TEST REPORT FORMS.
 - b. TEST CONDUCTORS AT SWITCHBOARDS, DISTRIBUTION CENTRES AND PANELBOARDS FOR INSULATION RESISTANCE TO GROUND (MEGGER TEST).
 - c. TEST SERVICE GROUNDING CONDUCTORS FOR GROUND RESISTANCE.
 - d. TEST ALL WIRING DEVICES FOR CORRECT OPERATION AND CIRCUITY.
 - e. LOAD BALANCE TESTING PERFORM LOAD TESTS WITH AS MANY LOADS ON AS POSSIBLE.

[illegible]

c:\Electrical Standards, Guidelines, Product Info. & Vendors\VER\20A\Standards\Shelter Drawings (Dubois-King)\Modified Design_04-21-25\Typical 20' Building(Dubois).dwg 6/5/2025 11:07 AM

ELECTRICAL ABBREVIATIONS LIST:	
(NOT ALL ABBREVIATIONS MAY BE USED)	
A	AMPERE(S)
A.C.	ALTERNATING CURRENT
AF	AMP FRAME
AFF	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AL	ALUMINUM
ALT	ALTERNATE
AT	AMP TRIP
ATS	AUTOMATIC TRANSFER SWITCH
AWG	AMERICAN WIRE GAUGE
BW	BUSWAY
C	CONDUIT (SEE RACEWAYS AND CONDUCTORS)
CB	CIRCUIT BREAKER
CC	CONTROL CABINET
CKT	CIRCUIT
CLG	CEILING
COND	CONDUCTOR
CONN	CONNECT
CP	CONTROL PANEL
CT	CURRENT TRANSFORMER
CU	COPPER
D.C.	DIRECT CURRENT
DM	DIMMER CONTROL
DISC	DISCONNECT
DN	DOWN
DP	DOUBLE POLE
DT	DOUBLE THROW
E.C.	ELECTRICAL CONTRACTOR
E.HTR	ELECTRIC HEATER
EM	EMERGENCY
EMT	ELECTRICAL METALLIC TUBING
EOL	END LINE RESISTOR
EWG	ELECTRIC WATER COOLER
EXIST	EXISTING
F	FUSE
F.P.C.	FIRE PROTECTION CONTRACTOR
FA	FIRE ALARM
FACP	FIRE ALARM CONTROL PANEL
FDR	FEEDER
FL	FLOOR
FLUOR	FLUORESCENT
FS	FUSIBLE SWITCH
FVNR	FULL VOLTAGE NON-REVERSING
G.C.	GENERAL CONTRACTOR
GEN	GENERATOR
GFCI	GROUND FAULT CIRCUIT INTERRUPTER
GFP	GROUND FAULT PROTECTION
GRD	GROUND
HOA	HAND-OFF-AUTO
HP	HORSEPOWER
HZ	FREQUENCY IN CYCLES PER SECOND
IC	INTERCOM
IMC	INTERMEDIATE METALLIC CONDUIT
ISO	ISOLATED NEUTRAL
JB	JUNCTION BOX
K	KEY OPERATED
KCMIL	THOUSAND CIRCULAR MIL(S)
kVA	KILOVOLT AMPERE(S)
KVAR	KILOVAR(S)
kW	KILOWATT(S)
LP	LIGHTING PANEL
LV	LOW VOLTAGE
MCB	MAIN CIRCUIT BREAKER
MCC	MOTOR CONTROL CENTER
MGST	MAGNETIC STARTER
MH	MANHOLE
MLO	MAIN LUGS ONLY
MTH	MOUNTING HEIGHT
MTR	MOTOR
MTS	MANUAL TRANSFER SWITCH
N.I.C.	NOT IN CONTRACT
NC	NORMALLY CLOSED
NF	NONFUSED
NO	NORMALLY OPEN
NTS	NOT TO SCALE
OC	OVER COUNTER
OL	OVERLOAD ELEMENT
P	PILOT INDICATOR
PF	POWER FACTOR
PNL	PANEL
PP	POWER PANEL
PRI	PRIMARY
PS	PULL SWITCH
PT	POTENTIAL TRANSFORMER
PVC	POLYVINYL CHLORIDE
R	RELAY
RC	REMOTE CONTROL
RECP	RECEPTACLE
RGS	RIGID METAL CONDUIT
S.S.	SOLID STATE
SEC	SECONDARY
SMR	SURFACE METAL RACEWAY
SP	SINGLE POLE
SPK	SPEAKER
SST	SOLID STATE TRIP
ST	SINGLE THROW
SW	SWITCH
SWBD	SWITCHBOARD
TEL	TELEPHONE
TB	TERMINAL BOX
TEMP	TEMPORARY
TYP	TYPICAL
UC	UNDER CABINET
UG	UNDERGROUND
UH	UNIT HEATER
UNG	UNGROUND
UON	UNLESS OTHERWISE NOTED
UPS	UNINTERRUPTED POWER SYSTEM
V	VOLT(S)
VA	VOLTAMP(S)
VAR	REACTIVE VOLT AMPERES
VP	VAPORPROOF
W	WATT(S)
WP	WEATHERPROOF
XFMR	TRANSFORMER
XP	EXPLOSION PROOF

MOUNTING ABBREVIATIONS LEGEND:		
SUBSCRIPT AT OUTLET	DESCRIPTION	
OC	OVER COUNTER OUTLET: INSTALL BOTTOM OF OUTLET BOX 1-1/2" ABOVE HIGHEST ELEMENT OF COUNTER (I.E., BACKSPLASH OR COUNTER TOP IF NO BACK SPLASH).	
CR	CASEWORK RECESSED OUTLET: MOUNT BOX IN CASEWORK VERTICAL SURFACE.	
EQ	EQUIPMENT OUTLET: FINAL TERMINATION METHOD AND EXACT LOCATION SHALL BE DETERMINED FROM EQUIPMENT MANUFACTURER'S APPROVED SHOP DRAWINGS.	
AFF	ABOVE FINISHED FLOOR	
AFG	ABOVE FINISHED GRADE	
MTH	MOUNTING HEIGHT	
RACEWAYS AND CONDUCTORS LEGEND:		
SYMBOL	DESCRIPTION	
	LOW VOLTAGE WIRING	
	CIRCUIT IN CONDUIT RUN IN-SLAB OR UNDERGROUND	
	CIRCUIT IN CONDUIT CONCEALED IN WALLS OR ABOVE CEILING WHERE POSSIBLE.	
	HOMERUN TO PANELBOARD OR AS NOTED	
	CONDUIT TURNING UP	
	CONDUIT TURNING DOWN	
RECEPTACLE OUTLETS LEGEND:		
SYMBOL	NUMBER BY THE SIDE OF SYMBOL DENOTES CIRCUIT NUMBER. DEVICE MOUNTING HEIGHTS ARE DENOTED BELOW UNLESS OTHERWISE NOTED ON PLANS. COORDINATE EXACT LOCATIONS AND ALL MOUNTING HEIGHTS W/ ARCHITECTURAL PLANS/SECTIONS.	
	DUPLEX CONVENIENCE OUTLET. MOUNT AT +18" AFF.	
	DOUBLE DUPLEX OUTLET (QUADPLEX RECEPTACLE). MOUNT AT +18" AFF.	
	DOUBLE DUPLEX OUTLET (QUADPLEX). INSTALLED FLUSH WITH FLOOR.	
	SINGLE DEDICATED OUTLET. MOUNT @ 18" AFF.	
	SPECIAL OUTLET AS NOTED ON DRAWINGS. MOUNT AT +18" AFF.	
	'R' DENOTES RANGE. 'D' DENOTES DRYER.	
	WIREMOLD 3000. DUPLEX RECEPTACLES SPACED 24" ON CENTER.	
	WALL MOUNT AT 36" AFF.	
GFCI, WP	DENOTES: GROUND FAULT CIRCUIT INTERRUPTER, WEATHERPROOF	
SWITCH LEGEND:		
SYMBOL	LOWER CASE LETTER (a, b, etc) BY THE SIDE OF SWITCH SYMBOL AND LIGHTING FIXTURE SYMBOL DENOTES GROUPS OF FIXTURES ON A PARTICULAR SWITCH. DEVICE MOUNTING HEIGHTS ARE DENOTED BELOW UNLESS OTHERWISE NOTED ON PLANS. COORDINATE EXACT LOCATIONS AND ALL MOUNTING HEIGHTS WITH ARCHITECTURAL PLANS AND SECTIONS.	
S	SINGLE POLE SWITCH. MOUNT AT 48" AFF.	
S ₂	TWO POLE SWITCH. MOUNT AT 48" AFF.	
S	THREE-WAY SWITCH. MOUNT AT 48" AFF.	
S _{HDA}	SINGLE POLE SWITCH FOR HAND-OFF-AUTO. MOUNT AT 48" AFF.	
S _{OB}	OIL BURNER SWITCH. MOUNT AT 48" AFF.	
S _{OR}	OVERRIDE SWITCH FOR AREA LIGHTING CONTROL PANEL. MOUNT AT 48" AFF.	
S _P	SINGLE POLE SWITCH WITH PILOT LIGHT. MOUNT AT 48" AFF.	
S _{WP}	SINGLE POLE SWITCH (WEATHERPROOF). MOUNT AT 48" AFF.	
	OCCUPANCY LIGHTING CONTROL SENSOR. CEILING MOUNT. "W" WALL MOUNTED	
	OCCUPANCY LIGHTING CONTROL SENSOR. WALL MOUNT AT 48" AFF.	
	DUAL LEVEL OCCUPANCY LIGHTING CONTROL SENSOR. WALL MOUNT AT 48" AFF.	
	LIGHTING CONTROL RELAY (PER MANUFACTURER'S INSTALLATION INSTRUCTIONS).	
LIGHTING LEGEND:		
CAPITAL LETTER ADJACENT TO LIGHTING FIXTURE INDICATES THE FIXTURE TYPE AS SPECIFIED IN THE 'LIGHTING FIXTURE SCHEDULE'. UNDERLINED NUMBER INDICATES CIRCUIT THAT THE FIXTURE IS ON. 'LOWER CASE' LETTER INDICATES THE CONTROL SWITCH. MOUNTING HEIGHTS ARE PER FIXTURE SCHEDULE. EXACT MOUNTING HEIGHTS SHALL BE COORDINATED WITH ARCHITECT.		
CEILING MOUNTED FIXTURE	WALL MOUNTED FIXTURE	DESCRIPTION
 ^{WW}	 ^{Q_b}	INCANDESCENT, HID OR SIMILAR LAMP FIXTURE
		SURFACE FLUORESCENT FIXTURE
		SURFACE FLUORESCENT CONTINUOUS LINEAR
		PENDANT CONTINUOUS LINEAR
		SURFACE BARE LAMP FLUORESCENT STRIP
		EXIT LIGHT. ARROWS DENOTE ROUTE OF EGRESS
		EMERGENCY BATTERY PACK
		ARROWS DENOTE AIMING DIRECTION ON LOCAL - NORMAL LTG CIRCUIT
^{B4}	^W	NIGHT-LIGHT* OPERATING 24/7 OR EMERGENCY FIXTURE

POWER APPURTANCES LEGEND:	
SYMBOL	REFER TO PLANS FOR EXACT QUANTITIES AND LOCATIONS.
	FLUSH MOUNTED PANELBOARD AND CABINET. MOUNT AT 6'-6" MAX. AFF TO TOP.
	SURFACE MOUNTED PANELBOARD AND CABINET. MOUNT AT 6'-6" MAX. AFF TO TOP.
	ELECTRICAL PULL BOX, SIZED AS REQUIRED OR AS SHOWN ON DRAWINGS.
	JUNCTION BOX (JB) (IN ACCESSIBLE LOCATION).
	JUNCTION BOX (JB) (IN ACCESSIBLE LOCATION) W/ FLEXIBLE CONDUIT TO EQUIPMENT AS SHOWN. - JUNCTION BOX SUBSCRIPTS: 'C' CONTROL, 'D' DATA, 'DT' DATA/TELEPHONE, 'F' FIRE ALARM, 'P' POWER, 'T' TELEPHONE.
	MOTOR. HORSEPOWER AS SHOWN ON DRAWINGS.
	DISCONNECT SWITCH. SIZE PER MANUFACTURER'S RECOMMENDATIONS. WEATHERPROOF (WP) WHEN LOCATED OUTSIDE.
	FUSED DISCONNECT SWITCH. SIZE AND FUSES PER MANUFACTURER'S RECOMMENDATIONS. WEATHERPROOF (WP) WHEN LOCATED OUTSIDE.
	DOUBLE DUPLEX (QUADPLEX RECEPTACLE). MOUNT AT +18" AFF.
	JUNCTION BOX (JB) (IN ACCESSIBLE LOCATION).
	SINGLE POLE MANUAL TIMER SWITCH. MOUNT AT 48" AFF.
	UTILITY METER. WALL MOUNT AT 5'-6" AFG TO CENTER OF METER MAX.
DATA, TELEPHONE, and CATV SYSTEMS LEGEND:	
SYMBOL	COORDINATE EXACT LOCATIONS AND MTG HTS W/ ARCH PLANS AND SECTIONS.
	TELEPHONE OUTLET MOUNTED @ 18" AFF OR AS NOTED. 'W' DENOTES WALL/'P' DENOTES PUBLIC.
	TELEPHONE OUTLET MOUNTED FLUSH WITH FLOOR.
	COMBINATION DATA/TELEPHONE OUTLET MOUNTED @ 18" AFF OR AS NOTED.
TMB	3/4" PLYWOOD TELEPHONE MOUNTING BOARD WITH #6 CU. GROUND AND DEDICATED DUPLEX CONVENIENCE OUTLET. FURNISH IN ACCORDANCE WITH TELEPHONE Co. REQUIREMENTS. SIZE AS NOTED.

GENERAL NOTES

- THE SCOPE OF WORK IS TO PROVIDE ALL LABOR, MATERIALS, SERVICES, SUPPLIES, TOOLS, EQUIPMENT, TRANSPORTATION, AND FACILITIES NECESSARY TO FURNISH AND INSTALL COMPLETE ELECTRICAL WORK AS CALLED FOR ON THE DRAWINGS, SPECIFIED, OR AS MAY REASONABLY BE IMPLIED AS BEING INCIDENTAL TO THIS WORK.
- SECURE AND PAY COSTS OF PERMITS, CERTIFICATES, LICENSES, INSPECTIONS, AND APPROVALS. ANY POWER OUTAGE SHALL BE SCHEDULED AND APPROVED BY THE OWNER.
- DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL ARRANGEMENT OF WORK. BASIC DESIGN CONCEPTS INDICATED ARE MINIMAL AND MUST BE EITHER FOLLOWED OR BETTERED. WORK IS NOT SHOWN IN DETAIL BUT IS INTENDED TO INCLUDE ITEMS NECESSARY FOR PROPER OPERATION AND COMPLETION. DO NOT SCALE DRAWINGS. VERIFY IN THE FIELD, ALL LOCATIONS, ELEVATIONS, AND DIMENSIONS.
- EXECUTE ALL WORK IN A NEAT AND WORKMANLIKE MANNER IN CONFORMANCE WITH BEST MODERN TRADE PRACTICE, BY COMPETENT, EXPERIENCED MECHANICS, PRESENTING A NEAT APPEARANCE WHEN COMPLETED. REPLACE WORK NOT APPROVED BY OWNER WITHOUT ADDITIONAL CHARGE.
- ALL MATERIALS AND INSTALLATION SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE, AND ALL CODES, REGULATIONS AND REQUIREMENTS OF ALL MUNICIPAL, STATE, FEDERAL AND OTHER PUBLIC OR PRIVATE AUTHORITIES WHICH HAVE JURISDICTION. IN EACH CASE, CODES ARE MINIMUM REQUIREMENTS.
- CONTRACTOR TO LIMIT 20A, 120V BRANCH CIRCUITS TO A MAXIMUM 1920VA LOAD AND 15A, 120V BRANCH CIRCUIT TO A MAXIMUM 1440VA LOAD. VERIFY IN THE FIELD, ALL BRANCH CIRCUITS AFFECTED BY RENOVATION.
- INSTALL A SEPARATE GREEN GROUND WIRE IN ALL POWER AND RECEPTACLE CIRCUITS.
- WHERE ELECTRICAL EQUIPMENT IS BEING FED FROM AN EXISTING SOURCE, EXTEND TO NEAREST BRANCH CIRCUIT WITH ADEQUATE CAPACITY.
- WHERE ELECTRICAL DEVICES AND FIXTURES ARE INDICATED THOSE LOCATIONS ARE APPROXIMATE AND NOT ALL ELECTRICAL DEVICES AND FIXTURES MAY BE INDICATED (FIELD VERIFY ALL ELECTRICAL ITEMS WHERE POSSIBLE).
- EACH OUTLET OR JUNCTION IN ANY OF THE WIRING SYSTEMS SHALL BE MADE IN A METALLIC JUNCTION BOX. SUCH BOX SHALL BE SUITABLE FOR THE SIZE AND NUMBER OF CONDUCTORS AND DEVICES TO BE INSTALLED, AS WELL AS THE CONDITION ENCOUNTERED. ALL SPLICES SHALL BE MADE WITH MECHANICAL CONNECTORS.
- DURING ROUGH IN AND FINISHED STAGES OF CONSTRUCTION, PROTECT AND KEEP CLEAN ALL ELECTRICAL EQUIPMENT, PANELS, FIXTURES AND DEVICES.
- VERIFY OF THE FINAL LOCATIONS OF MECHANICAL, HVAC AND OWNER'S EQUIPMENT AND POWER CONNECTION DETAILS SO THAT THE ASSOCIATED ELECTRICAL WORK WILL BE PROPERLY COORDINATED AND INSTALLED.
- THE FINISHED INSTALLATION SHALL BE COMPLETE IN EVERY RESPECT AND DETAIL, TESTED AND LEFT READY IN PERFECT OPERATING CONDITION FOR THE OWNER'S USE.
- MATERIALS AND EQUIPMENT SHALL BE LISTED BY UNDERWRITERS' LABORATORIES AND SHALL BE INSTALLED IN ACCORDANCE WITH SUCH LISTINGS.
- THE CONTRACTOR SHALL GUARANTEE THAT MATERIALS, EQUIPMENT AND WORKMANSHIP PROVIDED SHALL BE FREE FROM DEFECTS IN MATERIALS OR WORKMANSHIP FOR A PERIOD OF ONE YEAR FROM THE DATE OF ACCEPTANCE OF THE WORK DONE UNDER THIS CONTRACT, AND SHALL REPLACE PARTS FOUND TO BE DEFECTIVE WITHIN THE PERIOD COVERED BY SUCH GUARANTEE, WITHOUT COST TO THE OWNER.
- PROVIDE EACH ELECTRICAL FAN, PUMP OR HVAC UNIT WITH FUSED DISCONNECT, WEATHERPROOF (WP) NEMA 3R AND 12, FOR OUTDOOR, NEMA 1 FOR INDOOR. FUSE TO MATCH EQUIPMENT NAMEPLATE OF EQUIPMENT.
- ALL MECHANICAL EQUIPMENT SHALL HAVE HACR RATED BREAKERS PER NEC REQUIREMENTS.
- THE INTERIOR ELECTRICAL SYSTEM SHALL BE COMPLETELY AND EFFECTIVELY GROUNDED AS REQUIRED BY NEC. ALL METALLIC RACEWAYS SHALL BE ELECTRICALLY AND ELECTRICALLY SECURE AT ALL JOINTS AND AT ALL BOXES, CABINETS, FITTINGS, AND EQUIPMENT.
- COMPLETE ALL PANEL BOARD CIRCUITS DIRECTORY CARDS TO REFLECT AS-BUILT CONDITIONS.ALL RACEWAYS SHALL BE PROVIDED WITH EQUIPMENT GROUND CONDUCTOR. EQUIPMENT GROUNDING CONDUCTOR SHALL BE INSTALLED IN ALL ELECTRICAL RACEWAYS OR HOSPITAL GRADE MC CABLE AND SHALL BE SPECIFIED IN ACCORDANCE WITH NEC 250 AND SHALL BE CONTINUOUS.
- CLEARLY IDENTIFY ALL INCOMING CONDUCTORS BY CIRCUIT NUMBER DURING INSTALLATION IN THE DISTRIBUTION PANELS (E.G. CABLE MARKERS #1, #11 ETC).
- CONTRACTOR SHALL BE RESPONSIBLE FOR FURNISHING, INSTALLATION TESTING, CALIBRATING, AND OTHERWISE MAKING OPERATIONAL ALL DEVICES AND EQUIPMENT SHOWN ON THESE DRAWINGS.
- INSTALLATION SHALL BE MADE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
- THE INTENT OF THESE DRAWINGS AND SPECIFICATIONS IS TO OBTAIN A COMPLETE AND SATISFACTORY INSTALLATION. AN ATTEMPT HAS BEEN MADE TO SEPARATE AND DEFINE THE WORK. THESE DRAWINGS ARE DIAGRAMMATIC, BUT SHALL BE FOLLOWED AS CLOSELY AS ACTUAL CONSTRUCTION OF THE FACILITY AND THE WORK OF OTHER TRADES WILL PERMIT. THESE DRAWINGS UTILIZE SYMBOLS AND SCHEMATIC DIAGRAMS TO INDICATE VARIOUS ITEMS OF WORK. THEREFORE, NO INTERPRETATION WILL BE MADE FROM THE LIMITATION OF SYMBOLS AND DIAGRAMS THAT ANY ELEMENTS NECESSARY FOR THE COMPLETE INSTALLATION ARE EXCLUDED. THE ARCHITECT SHOULD BE NOTIFIED OF ANY DISCREPANCIES, OMISSIONS, CONFLICTS, OR INTERFERENCE WHICH MAY OCCUR BETWEEN VARIOUS DRAWINGS AND

ELECTRICAL DRAWING DIRECTORY	
EB-1	ELECTRICAL ABBREVIATIONS, LEGEND, AND GENERAL NOTES
EB-2	ELECTRICAL EXTERIOR ELEVATIONS
EB-3	ELECTRICAL INTERIOR FLOOR PLAN AND CEILING PLANS
EB-4	ELECTRICAL INTERIOR ELEVATIONS
EB-5	ELECTRICAL DETAILS
EB-6	ELECTRICAL SPECIFICATIONS

DuBois & King inc.

ENGINEERING • PLANNING • MANAGEMENT • DEVELOPMENT

97 PARK ST.
SPRINGFIELD, VT 05156
TEL: (802) 591-4326
www.dubois-king.com
RANDOLPH, VT
SO. BURLINGTON, VT
BEDFORD, NH
LACONIA, NH

© Copyright 2015 Dubois & King Inc.

PROFESSIONAL SEAL



VERMONT 12' x 20' EQUIPMENT SHELTER

DRAWN BY
EJD

CHECKED BY
WHH

PROJ. ENG.
LJH

DATE
JUNE 2025

D&K PROJECT #





D&K ARCHIVE #

SHEET TITLE

ELECTRICAL ABBREVIATIONS, LEGEND, AND GENERAL NOTES

SHEET NUMBER

EB-1



1. COORDINATE BUILDING CONSTRUCTION WITH STRUCTURAL DRAWINGS.
2. COORDINATE FINAL MECHANICAL EQUIPMENT LOCATIONS WITH MECHANICAL DRAWINGS.
3. COORDINATE WITH ELECTRICAL SITE DRAWINGS FOR FINAL CONNECTIONS OF GROUNDING CABLES

1 PROVIDE 3" SCH 40 PVC FROM UTILITY POLE TO TELECOM PULLBOX. PROVIDE 3" SCH 40 PVC THRU WALL INTO SHELTER.

2 PROVIDE RAB WPLED10

[illegible]

VERMONT 12' x 20'
EQUIPMENT
SHELTER


SHEET TITLE

ELECTRICAL EXTERIOR ELEVATIONS

DRAWN BY EJD	DATE JUNE 2025
CHECKED BY WHH	D&K PROJECT #
PROJ. ENG. LJH	D&K ARCHIVE #

SHEET NUMBER

EB-2



1 INTERIOR ELEVATION "A"
EB-4 $3/8" = 1'-0"$



3 INTERIOR ELEVATION "B"
EB-4 3/8" = 1'-0"




4 INTERIOR GROUNDING PLAN
EB-4 3/8" = 1'-0"



5 INTERIOR ELEVATION "D"
EB-4 $3/8" = 1'-0"$

1. CONTRACTOR TO CONFIRM ALL EQUIPMENT LOCATIONS WITH OWNER.
2. COORDINATE BUILDING CONSTRUCTION WITH STRUCTURAL DRAWINGS.
3. COORDINATE FINAL MECHANICAL EQUIPMENT LOCATIONS WITH MECHANICAL DRAWINGS.
4. COORDINATE WITH ELECTRICAL SITE DRAWINGS FOR FINAL CONNECTIONS OF GROUNDING CABLES.
5. ALL INTERIOR GROUND CABLES TO BE #2 THHN STRANDED GREEN UNLESS OTHERWISE NOTED.
6. ALL GROUNDING CABLES TO BE SECURED USING WAX STRING, PLASTIC WIRE TIES NOT PERMITTED
7. DO NOT INSTALL RECEPTACLES ABOVE FIXED ELECTRIC BASEBOARD HEATERS PER NEC AND MANUFACTURER'S REQUIREMENTS.

- 1 PROVIDE GROUNDING JUMPER CONNECTION PER NEC ARTICLE 250. PROVIDE BURNDY YGC, YGHC, OR EQUAL.
- 2 PROVIDE GROUNDING LUG CONNECTION PER NEC ARTICLE 250. PROVIDE BURNDY YGA, YGHA, OR EQUAL. PROVIDE WITH MIN. 1/4 x 20 SS CAP SCREWS, SS WASHER AND LOCK NUT.
- 3 PROVIDE CONNECTION OF CONDUIT AND WIRING TO GENERATOR PER MANUFACTURER'S RECOMMENDATIONS.

[illegible]

VERMONT 12' x 20'
EQUIPMENT
SHELTER

SHEET TITLE

ELECTRICAL
INTERIOR
ELEVATIONS

DRAWN BY EJD	DATE JUNE 2025
CHECKED BY WHH	D&K PROJECT #
PROJ. ENG. LJH	D&K ARCHIVE #



SHEET NUMBER

EB-4

BUS		225A		PANEL No. _____ ILC										LOCATION		EQUIPMENT ROOM	
PANEL RATING		NA												MOUNTING		SURFACE	
SUPPLY VOLTAGE		120/240V, 1Ø												DRAWING No.			
SERVICE		4-WIRE, W/ GROUND BUS															

WIRING		DESCRIPTION		VA OR W		BREAKER		CKT	BUS	CKT	BREAKER		VA OR W		DESCRIPTION		WIRING		
WIRE	COND			ØA	ØB	POLE	A	NO	CONN	NO	POLE	A	ØA	ØB			COND	WIRE	
4#2, 1#8G	2"	/	/			2		1	•	2	1	20				RECEPTACLES	3/4"	2#12, 1#12G	
		/	/			3		4	•	1	20					LIGHTING	3/4"	2#12, 1#12G	
		/	/			1	20	5	•	6	1	20				EXHAUST FAN	3/4"	2#12, 1#12G	
						1	20	7	•	8	1	20				SPARE			
						1	20	9	•	10	1	20				SPARE			
						1	20	11	•	12	1	20				SPARE			
								13	•	14						BLANK			
								15	•	16						BLANK			
								17	•	18						BLANK			
TOTAL 1										TOTAL 2									
TOTAL 2																			
TOTAL 1 + 2																			
CONN. LOAD TOTAL																			
AMPERES																			

MAIN BREAKER	200A/1P	MAIN LUGS	
FEEDER ENTRANCE BOTTOM		ENCLOSURE TYPE	
FEEDER SIZE	SEE ONE-LINE	ACCESSORIES	
SOURCE	SEE ONE-LINE		
PANEL TYPE	INTERSECT AA300G & 3R ILC		

[illegible]

VERMONT 12' x 20'
EQUIPMENT
SHELTER

SHEET TITLE

ELECTRICAL DETAILS

DRAWN BY EJD	DATE JUNE 2025
CHECKED BY WHH	D&K PROJECT #
ROJ. ENG. LJH	D&K ARCHIVE #

SHEET NUMBER

EB-5

23 0500 BASIC MECHANICAL REQUIREMENTS

A. QUALITY OF WORK

- CONTRACT DOCUMENTS ARE IN PART DIAGRAMMATIC, INTENDED TO CONVEY SCOPE & ARRANGEMENT OF WORK. CONSULT ELECTRICAL AND STRUCTURAL CONSTRUCTION DRAWINGS FOR FAMILIARITY WITH CONDITIONS AFFECTING WORK. VERIFY ALL SPACES IN WHICH WORK WILL BE PERFORMED BY ON-SITE MEASUREMENTS. DO NOT SCALE DRAWINGS.
- CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AS THERE MAY BE VARIOUS CONDITIONS AT THE SITE WHICH DO NOT SHOW ON THE ACCOMPANYING DRAWINGS, OR WHICH ARE AT VARIANCE WITH THE CONDITIONS INDICATED ON THE DRAWINGS. IT IS IMPORTANT THAT EACH BIDDER VISIT THE SITE TO BECOME ACQUAINTED WITH THE EXISTING CONDITIONS, AND TO TAKE THESE CONDITIONS INTO CONSIDERATION WHEN PREPARING THEIR PROPOSAL. EACH BIDDER SHALL OBTAIN ANY INFORMATION OR MAKE ANY MEASUREMENT DESIRED. LACK OF KNOWLEDGE RELATIVE TO THE EXISTING SITE CONDITIONS WILL NOT BE ALLOWED AS A BASIS FOR EXTRA COMPENSATION.
- PROVIDE ALL MATERIALS AND EQUIPMENT AND PERFORM ALL LABOR REQUIRED TO INSTALL COMPLETE AND OPERABLE MECHANICAL SYSTEMS AS INDICATED ON THE DRAWINGS, AS SPECIFIED AND AS REQUIRED BY CODE.
- ALL WORKSMANSHIP, MATERIALS, AND EQUIPMENT SHALL BE GUARANTEED FOR A PERIOD OF ONE YEAR AFTER ACCEPTANCE BY THE OWNER.

B. CODES/PERMITS

- WORK SHALL BE PERFORMED IN STRICT ACCORDANCE WITH NFPA, ASHRAE, UNDERWRITERS' LABORATORIES AND ALL MUNICIPAL, STATE AND OTHER AUTHORITIES. PUBLIC AND PRIVATE, HAVING JURISDICTION. REPORT ALL DISCREPANCIES WITH SUCH REGULATIONS TO ENGINEER AND DO NOT PROCEED WITH ANY WORK UNTIL WRITTEN AUTHORIZATION IS RECEIVED FROM THE ENGINEER.
- ALL NECESSARY FEES, PERMITS, AND APPROVALS AS REQUIRED BY THE WORK OF THESE DRAWINGS AND SPECIFICATIONS SHALL BE OBTAINED AND PAID FOR BY THIS CONTRACTOR.
- NOTHING CONTAINED IN THE SPECIFICATIONS OR INDICATED ON THESE DRAWINGS SHALL BE CONSTRUED TO CONFLICT WITH APPLICABLE PORTIONS OF ANY LAWS, ORDINANCES, REGULATIONS, OR CODES.

C. COORDINATION OF WORK

- COORDINATE CONSTRUCTION OF ALL MECHANICAL WORK WITH ARCHITECTURAL, STRUCTURAL, CIVIL, AND ELECTRICAL WORK SHOWN ON OTHER CONTRACT DOCUMENTS.
- CONCRETE HOUSEKEEPING PADS TO SUIT MECHANICAL EQUIPMENT SHALL BE SIZED AND LOCATED BY THE MECHANICAL CONTRACTOR. MINIMUM CONCRETE PAD THICKNESS SHALL BE 4 INCHES. PAD SHALL EXTEND BEYOND THE EQUIPMENT A MINIMUM OF 4 INCHES ON EACH SIDE. CONCRETE HOUSEKEEPING PADS SHALL BE PROVIDED BY THE GENERAL CONTRACTOR; IT SHALL BE THE RESPONSIBILITY OF THE MECHANICAL CONTRACTOR TO COORDINATE SIZE AND LOCATION OF CONCRETE HOUSEKEEPING PADS WITH THE GENERAL CONTRACTOR.
- WHEN MECHANICAL WORK (HVAC, PLUMBING, FIRE PROTECTION, ETC.) IS SUBCONTRACTED, IT SHALL BE THE MECHANICAL CONTRACTOR'S RESPONSIBILITY TO COORDINATE SUBCONTRACTORS' AND THE ASSOCIATED CONTRACTS. WHEN DISCREPANCIES ARISE PERTAINING TO WHICH CONTRACTOR PROVIDES A PARTICULAR ITEM OF THE MECHANICAL CONTRACT OR WHICH CONTRACTOR PROVIDES FINAL CONNECTIONS FOR A PARTICULAR ITEM OF THE MECHANICAL CONTRACT, IT SHALL BE BROUGHT TO THE ATTENTION OF THE MECHANICAL CONTRACTOR, WHOSE DECISION SHALL BE FINAL.
- THE LOCATIONS OF ALL ITEMS SHOWN ON THE DRAWINGS OR CALLED FOR IN THE SPECIFICATIONS ARE APPROXIMATE AND NOT DEFINITELY FIXED BY DIMENSIONS. THE EXACT LOCATIONS NECESSARY TO SECURE THE BEST CONDITIONS AND RESULTS MUST BE DETERMINED BY THE PROJECT SITE CONDITIONS AND SHALL HAVE THE APPROVAL OF THE ENGINEER BEFORE BEING INSTALLED. DO NOT SCALE THE DRAWINGS.
- COORDINATE LOCATIONS AND SIZES OF ALL FLOOR, WALL, AND ROOF OPENINGS WITH ALL OTHER TRADES INVOLVED. ALL OPENINGS IN WALLS FOR PIPING, CONDUIT, DUCTWORK, ETC., SHALL BE FIRE STOPPED.


23 0553 MECHANICAL IDENTIFICATION

- EQUIPMENT NAMEPLATES. IDENTIFY ALL SCHEDULED EQUIPMENT WITH PLASTIC NAMEPLATES. PLATES ARE LAMINATED THREE-LAYER PLASTIC WITH ENGRAVED LETTERS. LETTERING IS WHITE AND ¼ INCH HEIGHT. BACKGROUND COLOR IS BLACK.

23 3100 DUCTWORK


- FABRICATE DUCTWORK FROM FIELD VERIFIED DIMENSIONS. FABRICATE DUCTWORK IN ACCORDANCE WITH SMACNA GUIDELINES (LATEST EDITION). PRIOR TO FABRICATING DUCTWORK VERIFY CEILING CLEARANCES WITH STRUCTURE, PIPES, ETC. COORDINATE THE INSTALLATION OF DUCTWORK WITH SPRINKLER PIPING. INSTALL DUCTWORK PRIOR TO INSTALLING ANY PIPING AND ELECTRICAL WORK TO REDUCE CONFLICTS.
- ALL DUCTWORK DIMENSIONS SHOWN ON PLANS ARE CLEAR INTERNAL SIZES.
- ALL DUCTWORK SHALL BE DESIGNED AT A MINIMUM CLASS OF 2 INCH WATER GAGE, SEAL CLASS 'A'.

MECHANICAL LEGEND:



BASIS OF DESIGN

UPDATES TO BASIS OF DESIGN MADE ON 6/20/2025 ARE THE RESULT OF OWNER-REQUESTED SUBSTITUTIONS / EQUIPMENT SELECTIONS.
GAS DETECTOR HAS BEEN REMOVED FROM SCOPE BASED ON REVISED BATTERY TYPE NOT REQUIRING GAS DETECTION AS DETERMINED BY OWNER.
OWNER-SELECTED INTAKE DAMPER TO REPLACE INTAKE LOUVER IS A PASSIVE DAMPER, WHICH WOULD BE OPENED BY THE OPERATION OF THE FAN. NO INFORMATION ON NEW DAMPER'S EXTERNAL STATIC PRESSURE REQUIREMENTS. ESP. REQUIREMENT FOR REVISED SYSTEM WILL BE HIGHER THAN INITIAL DESIGN.
ACTUAL AIRFLOW WILL BE LOWER THAN SCHEDULED. OWNER-SELECTED FAN IS NOT CAPABLE OF PROVIDING BASIS OF DESIGN AIRFLOW AND STATIC PRESSURE REQUIREMENTS OF THE INITIAL AND CURRENT SYSTEM.



DAMPER SCHEDULE

SYMBOL	MANUFACTURER AND MODEL	TYPE	SIZE W x D (IN)	CFM	SPD ("WC)	MATERIAL/ FINISHING	REMARKS
D-# CFM							
D-1	DAYTON 4YN17	PASSIVE DAMPER	27 x 27	660	~	ALUMINUM / NOTE 2	PROVIDE WITH BIRD SCREEN NOTES 1, 2, 3

NOTES:

- NO STATIC PRESSURE DROP CURVE PROVIDED BY MANUFACTURER'S DATA. ASSUMED >0.015 SPD. FROM INITIAL BASIS OF DESIGN LOUVER DUE TO PASSIVE DAMPER OPERATION FROM EF-1 STATIC PRESSURE.
- PROVIDE COLOR CHART TO OWNER FOR COLOR SELECTION.
- PROVIDE WITH DAYTON 1WBV9 45" 28"x28" WEATHERHOOD.

FAN SCHEDULE

SYMBOL	MANUFACTURER AND MODEL	FAN TYPE	CFM	ESP ("WC)	POWER	RPM	SONES	VOLTS/ø	DRIVE TYPE	REMARKS
EF-#										
EF-1	DAYTON 484X39 WITH 18D55R WEATHERHOOD	IN-LINE	660	0.375	1/6 HP	1550	6.4	115/1	DIRECT	ALL NOTES

NOTES:

- FAN HAS A PERMANENT SPLIT CAPACITOR MOTOR.
- FAN IS ACTIVATED BY LINE VOLTAGE REVERSE ACTING THERMOSTAT (85 DEG F, ADJUSTABLE). PROVIDE DAYTON 4LZ94 WALL MOUNT MECHANICAL THERMOSTAT. PROVIDE DAYTON 48C172 WALL MOUNT SPEED CONTROL FOR BALANCING FLOW AND MOUNT ADJACENT TO THE THERMOSTAT. LABEL THERMOSTAT WITH "EXHAUST FAN EF-1".
- FAN INLET SHALL HAVE ½" MESH SCREEN.
- LINE VOLTAGE MOTORIZED INTAKE ISOLATION DAMPER (NORMALLY CLOSED) IS INTERLOCKED TO EXHAUST FAN EF-1 TO OPEN UPON FAN ACTIVATION.
- FAN IS 21" LONG, 17" WIDE, 17" HIGH, WITH 16" BLADES. VERIFY THAT FAN WILL FIT WITHIN SUBMITTED WALL FRAMING. FAN WEIGHT IS 56 LB. FAN COMES INSTALLED WITH BACKDRAFT DAMPER, MOUNT FAN TO WALL FLANGE.
- FAN FLOW RATE AND ESP ARE EXISTING FROM INITIAL MODEL SELECTED PRIOR TO REVISIONS. REVISED MODEL SELECTED BY OWNER. REVISED MODEL PROVIDES LIMITED FLOW RATE AND STATIC PRESSURE DATA: 1381 CFM AT 0.00" ESP, AND 770 CFM AT 0.125" ESP. REVISED MODEL IS NOT CAPABLE OF PROVIDING INITIAL BASIS OF DESIGN FLOW RATE AT REQUIRED STATIC PRESSURE. REQUIRED STATIC PRESSURE EXPECTED TO BE HIGHER THAN INITIAL BASIS OF DESIGN WITH THE ADDITION OF DAMPER D-1.

DuBois & King Inc.

ENGINEERING • PLANNING •
MANAGEMENT • DEVELOPMENT
6 GREEN TREE DRIVE
SO. BURLINGTON, VT 05403
TEL: (802) 878-7661
FAX: (866) 783-7101
www.dubois-king.com
RANDOLPH, VT
SPRINGFIELD, VT
BEDFORD, NH
© Copyright 2019 DuBois & King Inc.



SVD	CK'D
SER	BY
OWNER-DIRECTED UPDATES	DESCRIPTION
6/20/2025	DATE
1	NO.



VERMONT 12x20
EQUIPMENT SHED

SHEET TITLE

MECHANICAL
NOTES, FLOOR PLAN,
AND SCHEDULES

DRAWN BY	DATE
GXS	NOV 2019
CHECKED BY	D&K PROJECT #
MAS	
PROJ. ENG.	D&K ARCHIVE #
LJH	

SHEET NUMBER

M1