

**STATE OF VERMONT
PUBLIC UTILITY COMMISSION**

Case No. 26-__-PET

Petition of Green Mountain Power for a Certificate of Public Good, pursuant to 30 V.S.A. § 248, authorizing the rebuild of the Georgia Substation located at 2066 Ballard Road in the Town of Georgia, Vermont	
--	--

DIRECT TESTIMONY OF WITNESS
JOHN R. FISKE
ON BEHALF OF GREEN MOUNTAIN POWER

April 8, 2026

Mr. Fiske describes the equipment arrangement proposed for the GMP Georgia Substation located at 2066 Ballard Road in the Town of Georgia, Vermont, the required temporary substation, reconfiguration of the existing 34.5 kV transmission line 127, and the temporary and proposed modification of the existing two (2) distribution circuits. He also provides the project construction schedule.

DIRECT TESTIMONY OF JOHN R. FISKE

1 **1. Q. Please state your name, occupation, and business address.**

2 **A.** My name is John Fiske, and I have been retained by Green Mountain Power
3 (GMP) for Project Manager Services. I am an employee of JRF Engineering, PC located in
4 Rutland, Vermont 05701.

5
6 **2. Q. Please describe your background and experience.**

7 **A.** I earned a Bachelor of Science Degree in Electrical Engineering from the
8 University of Vermont and am a Licensed Professional Engineer in the State of Vermont. Prior
9 to my current employment, I held the position of Director of Engineering at Green Mountain
10 Power, Manager of Substation Design/Relay Protection, System Protection Engineer, and
11 Division Engineer at Central Vermont Public Service Corporation (CVPS). I also worked as a
12 Manager of Engineering and System Protection Engineer at Vermont Electric Power Company in
13 Rutland, Vermont.

14
15 **3. Q. Have you previously testified before the Vermont Public Utility Commission**
16 **(the “Commission”)?**

17 **A.** Yes, I have provided testimony in numerous matters. Most recently, I have
18 testified in the following cases: Docket Nos. 7857 (GMP Randolph 15 Substation), 7887 (GMP
19 Vernon Road Substation Breaker Addition), 8029 (GMP St. Johnsbury Substation 16 Upgrade),
20 8030 (GMP Woodstock Substation Upgrade), 8205 (GMP Georgia Interconnection Project),
21 8308 (GMP Waterbury/Duxbury Substation), 2017 GMP rate case (Case No. 17-3112-INV),

1 GMP Airport Substation (Case No. 18-2910-PET), GMP B20, B22 and Lowell Substation
2 upgrade Project (Case No. 19-4464-PET), GMP East St. Albans installation of two SCADA-
3 controlled capacitor banks and other substation upgrades (Case No. 20-0295-PET), GMP North
4 Brattleboro Substation rebuild (Case No. 20-0776-PET), GMP Castleton Substation upgrade
5 (Case No. 20-3966-PET), GMP Putney Substation upgrade (Case No. 21-1559-PET), GMP
6 Pleasant Street Substation upgrade (Case No. 21-4149-PET), GMP Richmond Substation
7 upgrade (Case No. 21-5164-PET), GMP Rebuild 46kV Transmission Line Taftsville substation
8 to the Windsor substation (Case No. 22-3085-PET), GMP Hydeville Substation Upgrade (Case
9 22-4230-PET), VELCO St. Johnsbury Substation Upgrade (Case No. 23-3761-PET), GMP
10 Upgrades and resupply of the 46kV Transmission Line 60 in the Towns of Salisbury,
11 Middlebury, New Haven, and Weybridge, Vermont (Case No. 24-0636-PET), GMP relocation
12 and rebuild of the Fair Haven Substation (Case No. 25-0593-PET), VELCO Sandbar Advanced
13 Power Flow Controller (Case No. 25-1259-PET) and GMP Rebuild of the Irasville #39
14 Substation (Case No. 25-2468-PET).

15

16 **4. Q. What is the purpose of your testimony?**

17 **A.** I describe the proposed construction of the rebuilt Georgia Substation, the
18 temporary substation, the reconfiguration of the 34.5 kV transmission line 127, the
19 temporary and proposed modifications of the 12.47 kV distribution circuits, as well as the
20 construction schedule. My testimony supports a finding that the proposed rebuilt Georgia
21 Substation will be designed and constructed in accordance with the requirements of the
22 National Electrical Safety Code (NESC).

1 **5. Q. Please describe the existing GMP Georgia Substation.**

2 **A. The existing GMP Georgia Substation Operating Diagram is Exhibit GMP JRF-**

3 **1.** The existing GMP Georgia Substation consists of the following: a driveway mostly covered
4 with grass except for an approximate 13' wide x 45' long gravel area intersecting with Ballard
5 Road, and a fenced-in yard (approximately 69' x 78' in size); one (1) 34.5 kV steel structure; one
6 (1) Gang Operated Air Break (GOAB) disconnect (354); three (3) 34.5 kV power fuses for
7 transformer protection (PF-T1); three (3) 34.5 kV station class lightning arresters, one (1) 1974
8 vintage 10/14 MVA 34.5/12.47 kV power transformer (T1); three (3) 12.47kV station class
9 lightning arresters, one (1) 12.47 kV wooden structure; one (1) 12.47 kV steel structure, three (3)
10 bus voltage instrument transformers (VT2) with associated fuses (PF-VT2), one (1) 25 kVA
11 station service transformer (SS1) with associated fusing (PF-SS1); two (2) 12.47 kV Line
12 breakers (70 & 71); six (6) sets of three 12.47 kV single blade line breaker disconnect switches
13 (719, 718, 709, 708); three (3) 438 amp regulators, three (3) 328 amp regulators; six (6) 12.47
14 kV intermediate class lightning arresters.

15

16 **6. Q. Please describe the equipment arrangement proposed for the rebuilt Georgia**
17 **Substation.**

18 **A. The proposed rebuilt Georgia Substation Operating Diagram, and Site Plan are**
19 provided as **Exhibit GMP JRF-2**, and **Exhibit GMP JRF-3**, respectively. The proposed rebuilt
20 Georgia Substation Plan View, North Elevation AA, East Elevation BB, West Elevation CC, &
21 South Elevation DD are attached as **Exhibit GMP JRF-4**, **Exhibit GMP JRF-5**, **Exhibit GMP**

1 **JRF-6, Exhibit GMP JRF-7, and Exhibit GMP JRF-8**, respectively. The proposed oil
2 containment appears as **Exhibit GMP JRF-9**.

3 The plans for the proposed rebuilt Georgia Substation construction will consist of:

- 4 (1) Installation of a new driveway, vehicle turn around, and access to the
5 transmission line 127. The new proposed gravel driveway is
6 approximately 27' wide x 123' long and the associated vehicle turn around
7 is approximately 18' wide x 20' long. The new proposed 12' wide
8 transmission line access road will extend from the eastern end of the
9 substation driveway approximately 272' feet east where it will intersect
10 with an existing farm road providing access to the transmission line.
11 Upgrades to the existing farm road are not proposed. The new substation
12 driveway and transmission access road is the proposed route to access the
13 temporary substation.
- 14 (2) Installation of a new fence with foundations to create a polygon shaped
15 fenced in yard (approximately 110' x 135' in area, 9' high). Please see
16 Exhibit GMP JRF-4 for the details of the fence layout. The new fence will
17 meet NESC requirements and facilitate access to construction and
18 maintenance vehicles. Substation yard lighting and security cameras will
19 be installed on steel poles inside the substation fence to accommodate
20 maintenance, emergency, and surveillance activities. The steel poles will
21 be approximately 18 feet in height. Additional yard lighting will be
22 installed on the fence. The yard lighting will be operated from a switch

- 1 located within an enclosure mounted to the substation steel tower leg.
- 2 (3) Installation of new equipment foundations, ground grid, and below grade
3 trench and conduit systems.
- 4 (4) Installation of two (2) new 34.5 kV line vacuum circuit breakers (VCB)
5 (B-34 & B-35), two bays of 34.5 kV steel structure (each 18 feet wide, 26
6 feet 2 inches tall, and 16 feet deep) with associated 16 foot lightning rods,
7 34.5 kV bus work and insulators, two (2) sets of three 34.5 kV single
8 blade disconnect switches (349, 348, 359, 358), two (2) gang operated
9 load break (GOLB) switches (X999, 355), two (2) 34.5 kV phase to phase
10 line potential transformers (VT34 & VT35) with associated fusing (PF-
11 VT34 & PF-VT35), three (3) 34.5 kV phase to ground bus potential
12 transformers (VT1) with associated fusing (PF-VT1), and six (6) 34.5 kV
13 intermediate class lightning arresters.
- 14 (5) The existing 10/14 MVA, 34.5/12.5 kV power transformer (T1) will be
15 replaced with an in kind replacement, along with three (3) single blade
16 disconnect switches (929), three (3) 34.5 kV station class lightning
17 arresters, three (3) 12.5 kV station class lightning arresters and one (1)
18 pedestal mounted GOLB switch (928).
- 19 (6) Installation of two (2) new 12.47 kV VCBs (70 & 71), two (2) bays of
20 steel structures (each 18 feet wide, 26 feet 2 inches tall, and 5 feet deep)
21 with associated 16 foot lightning rods, 12.47 kV bus work and insulators,
22 five (5) sets of three 12.47 kV single blade line disconnect switches (719,

1 718, 709, 708, X888), three (3) 12.47 kV phase to ground bus potential
2 transformers (VT2) with associated fusing (PF-VT2), two (2) 12.47 kV
3 phase to ground line potential transformers (VT70 & VT71) with
4 associated fusing (PF-VT70 & PF-VT71), six (6) 12.47 kV intermediate
5 class lightning arresters, and a station service transformer (SS1) with
6 associated fusing (PF-SS1).

7 (7) Installation of six (6) new 438 Amp voltage regulators with associated
8 regulator controls.

9 (8) Installation of a new control building (approximately 18 feet wide, 28 feet
10 long, 15 feet tall with a peaked roof). The control building will house the
11 protection and control switchgear, the communications equipment, the DC
12 battery system, the AC and DC distribution panels, the Supervisory
13 Control and Data Acquisition (SCADA) equipment, and other various
14 control equipment. The substation will utilize fiber optic cable for
15 SCADA communications between the GMP Control Center and the
16 Remote Terminal Unit (RTU) in the substation, voice-grade
17 communications, and engineering access for retrieval of fault records from
18 the microprocessor relays. The fault records are utilized to estimate fault
19 locations and analyze power system events for restoration efforts. The
20 SCADA system will provide control and monitoring of the two (2) 34.5
21 kV VCBs (B-34 & B-35), the two (2) 12.47 kV VCBs (70 & 71), and the
22 regulator controls for the two 12.47 kV distribution circuits. A GPS

1 receiver antenna and a “Gatekeeper” antenna (each approximately 12” in
2 height) will be mounted on the side of the control building. The GPS
3 antenna will provide accurate time stamp for the SCADA system and
4 microprocessor relay event records. The “Gatekeeper” antenna is to
5 collect data from Smart Meters.

6 (9) Installation of a new security system. The security system will be housed
7 in the new control building.

8 The proposed rebuilt Georgia Substation improves equipment layout and clearances for
9 operational activities and improves system reliability and stability. GMP Witness Kamran
10 Hassan testifies further as to Project need and history.

11
12 **7. Q. Will an oil containment system be added to the proposed rebuilt Georgia**
13 **Substation?**

14 **A.** Yes, a new oil containment system will be constructed with a perimeter berm
15 including filter drains to allow rainwater to escape. The proposed oil containment system has a
16 volume of no less than 110% of the proposed power transformer’s oil capacity plus 5 inches of
17 freeboard rain. Please see Exhibit GMP JRF-9 for the details of the oil containment design.

18
19 **8. Q. Please describe the existing Transmission Line 127 connected to the existing**
20 **Georgia Substation.**

21 **A.** The existing Transmission Line 127 (TL127) is a 7.57 mile 34.5 kV networked
22 line that serves three distribution substations. The line serves the Georgia distribution substation

1 with an 0.06-mile-long radial tap off from TL127 P105X. There are no automatic sectionalized
2 devices on the TL127 between Nason Street and Ballard Road substations. The two other
3 distribution stations served off from TL127 are radial taps and have SCADA controlled Motor
4 Operated Load Breaker (MOLB) switches on each side of the radial taps for sectionalizing.

5

6 **9. Q. Please describe the Transmission Line (TL127) modifications associated with**
7 **the rebuilt Georgia Substation.**

8 **A.** The proposed TL127 modifications include the installation of two (2) 55' poles
9 (P105 & PX106), six (6) 50' pole (P104X, P105-1, P105-2, P105-3, P105-4, & P106) and one
10 (1) 45' pole (P105-2-1), approximately 709' of three phase overhead transmission line, one (1)
11 SCADA controlled MOLB switch (457) to create a loop feed into the Georgia Substation. The
12 line modifications also include the retirement of approximately 382' of three phase overhead
13 transmission line, one (1) 45' 1955 vintage pole, one (1) 45' 1986 vintage pole, one (1) 45' 1988
14 vintage pole and one (1) 65' 1978 vintage pole.

15 The proposed SCADA controlled MOLB switch (457) and associated lightning arresters
16 will be installed on P105-2-1 to facilitate a bypass of the rebuilt Georgia Substation for future
17 maintenance efforts. This bypass switch is located between the new P105-2 and the new P105-3
18 on TL127.

19 Two sets of three (3) in-line disconnect switches are proposed for working clearance
20 during construction of the proposed rebuilt Georgia Substation and for future maintenance
21 efforts, one set (356) between new P105-2 and new P105-2-1 with the second set (346) between
22 new P105-2-1 and new P105-3.

1 **10. Q. Please describe the distribution line modifications associated with the rebuilt**
2 **Georgia Substation.**

3 A. There are two (2) existing 12.47 kV three phase overhead distribution circuits (70
4 & 71) emanating from the Georgia substation. The proposed substation will retain the existing
5 distribution line right of way for both the 70 and 71 circuits. On the 70 circuit, the existing 40'
6 1986 vintage G70 P1 pole will be replaced with a 50' pole to accommodate the installation of an
7 alternate station service transformer and the installation of secondary cable from G70 P1 to the
8 Georgia Substation. On the 71 circuit, the existing 45' 1977 vintage G71 P1 pole will be
9 replaced with a 50' pole to accommodate the temporary substation connection to the existing
10 distribution line and fiber cable. The existing in-line single blade disconnects on the 70 circuit
11 (632) and 71 circuit (442) will be retired and two sets of pole mounted single blade disconnects
12 will be installed, one on G70 P1(704) and the other on G71 P1 (714).

13 A new 50' pole will be installed at G70 P3 equipped with a permanent Gang Operated
14 Load Break switch (7017) to provide a circuit tie for future maintenance needs.
15 Please see Exhibits GMP JRF-2 and GMP JRF-3 for the details of the distribution line design.

16

17 **11. Q. Will a temporary substation be necessary to serve customers during**
18 **construction?**

19 A. Yes, the construction of the proposed rebuilt Georgia Substation will require the
20 use of a temporary substation to serve customers during construction. The proposed rebuilt
21 Georgia Substation has been designed to accommodate the installation of a portable substation
22 for future needs.

1 **12. Q. Please describe the proposed temporary Georgia Substation.**

2 **A.** The proposed temporary Georgia Substation’s details are shown in the Site View
3 provided in Exhibit GMP JRF-3 and the Temporary Substation Operating Diagram provided in
4 **Exhibit GMP JRF-10.** The temporary substation will be supplied from the Transmission Line
5 127 Temporary Pole TP3. The plans for the proposed temporary Georgia Substation
6 construction will consist of:

- 7 (1) Installation of a temporary fence to create a fenced in yard (approximately 44’
8 x 80’ in area, 8’ high). The temporary fence will meet NESC requirements
9 and facilitate access to construction and maintenance vehicles.
- 10 (2) Installation of a temporary 45’ pole (TP4) equipped with a set of three single
11 blade disconnects (T999).
- 12 (3) Installation of a mobile substation complete with one (1) 34.5 kV GOAB
13 switch (X919), three (3) 34.5 kV power fuses (PF-T1), and three (3) 34.5 kV
14 station class lightning arresters, one (1) 15 MVA Power Transformer, three
15 (3) 12.47 kV station class lightning arresters, one (1) 12.47 kV distribution
16 breaker, three (3) 668-amp bus regulators, one (1) single phase station service
17 transformer (SS1) with associated fuses (TPF-SS1), one (1) three phase
18 station service (SS2), three (3) – 668 amp regulators, and a new 45’ pole
19 (TP5) equipped with a set of three single blade disconnects (T888).
- 20 (4) The temporary substation will be constructed with oil containment with a
21 volume of no less than 110% of the proposed power transformer’s oil capacity
22 plus 5 inches of freeboard rain. The oil containment will be constructed with

1 a perimeter berm and include filter drains to allow rainwater to escape.

2 (5) Installation of temporary relay and communication equipment cabinets.

3 The fence, oil containment berm and filters, poles and all equipment associated
4 with the temporary substation will be removed after the project is complete. The gravel
5 and ground grid will be removed, and the area will be topsoiled, seeded and mulch after
6 construction.

7

8 **13. Q. Please describe the temporary transmission line construction required to**
9 **connect the temporary substation.**

10 **A.** A temporary 34.5 kV line bypass is proposed to maintain continuity of TL127
11 during construction of the proposed lines into the Georgia Substation. The bypass consists of
12 replacing TL127 P104X with a new 50' pole, addition of two (2) temporary 50' poles (TP1 &
13 TP2) and associated guying, and approximately 225' of three phase 34.5 kV conductor. The
14 proposed temporary GOLB switch (T820) on P106, the set of three in-line disconnects (T643)
15 between PX106 and TP3, the set of three in-line disconnects (T666) between P104X and TP1,
16 and the set of three in-line disconnects (T653) between P104X and P105 will be installed as
17 sectionalizing points to facilitate the installation of a temporary substation and construction of
18 the loop feed into the Georgia Substation without a customer outage.

1 **14. Q. Please describe the temporary distribution line construction required to**
2 **connect the temporary substation to the existing distribution circuits.**

3 **A.** A temporary three phase overhead 12.47kV distribution line will extend from the
4 temporary substation pole TP5 to G71 P1, approximately 425 feet via two (2) 50' poles (TP6 &
5 TP7). At G71 P1, the temporary overhead line will connect to the existing 71 circuit.

6 The existing pole at G71 P2 will be replaced with a new 50' pole to accommodate the
7 installation of a temporary recloser (TPG71) equipped with six (6) intermediate class lightning
8 arresters and associated bypass fuses (TP-F71).

9 The existing pole at G70 P2 will be replaced with a new 50' pole to accommodate the
10 installation of a temporary recloser (TPG71) equipped with six (6) intermediate class lightning
11 arresters and associated bypass fuses (TP-F72).

12 Temporary overhead fiber optic cable will be installed from the temporary substation to
13 each of the temporary reclosers at G70 P2 and G71 P2. This temporary fiber will be installed on
14 the temporary distribution line to G71 P1 where it will then follow the existing distribution line
15 to G71 P2 providing communications to the temporary recloser on this pole. The fiber optic
16 cable will then extend from G71 P2 to G70 P2 via G70 P3 to provide communications to the
17 recloser on G70 P3. These reclosers are being installed to maintain reliability of the 70 and 71
18 circuits while in the temporary configuration and will be removed after the proposed Georgia
19 substation is commissioned.

1 **15. Q. Will an outage be necessary to perform the proposed Georgia Substation**
2 **upgrades?**

3 **A.** No, the construction of the substation upgrades will be performed without an
4 outage of the Georgia Substation.

5

6 **16. Q. Will lay down areas be utilized during construction?**

7 **A.** No, lay down areas will not be utilized during construction.

8

9 **17. Q. Will the Project have any adverse effects on the safety of the public or**
10 **adjoining landowners?**

11 **A.** The Project will be designed and constructed in accordance with current National
12 Electrical Safety Code requirements. GMP will use quality materials and adhere to careful
13 construction practices throughout the construction phase. The Project will not unnecessarily or
14 unreasonably endanger the public or adjoining landowners.

15

16 **18. Q. What is the anticipated construction schedule?**

17 **A.** Subject to Commission approval, this Project is proposed to commence March
18 2027 and conclude by September of 2027.

19

20 **19. Q. What are the anticipated construction hours for the Project?**

21 **A.** Construction hours for the Project will be from 7:00 a.m. to 7:00 p.m. Monday
22 through Friday, 8:00 a.m. to 5:00 p.m. on Saturday, and shall cease on Sundays and state and

1 federal holidays except where construction activities must be performed during required outages
2 needed to maintain system reliability.

3

4 **20. Q. Does this conclude your testimony?**

5 **A. Yes.**

DECLARATION OF JOHN R. FISKE

I declare that the testimony and exhibits that I have sponsored are true and accurate to the best of my knowledge and belief and were prepared by me or under my direct supervision. I understand that if the above statement is false, I may be subject to sanctions by the Commission pursuant to 30 V.S.A. § 30.

April 8, 2026
Date

/s/ John R. Fiske
John R. Fiske