

Q.BED:SWANTON1-9: Does an SIS performed by ISO-NE determine whether or not there will be curtailments of other generation, or that the compensation of other generation will or will not be affected? Please explain your response.

RESPONSE:

Curtailments are typically considered an operational condition based upon available generation and condition of the transmission system (i.e. line outages). System impact studies examine the capability of the transmission system to accommodate a generator interconnection without adversely affecting the system. If adverse effects are observed, the generator is required to mitigate the adverse effects.

Response provided by:

David P. Estey, PE, RLC Engineering