

Battery Usage 2019 to 2023

Source: GMP.DPS.Q31a

Energy Delivered from the Battery (No. of Events)										
Maximum Outage Duration hours	Maximum Outage Duration Minutes	Events	0.00 Kwoh	More than 0 and less than 0.5 kWh	More than 0 and Less than 1 kWh	Greater than 13 kWh	% Delivering 0 kWh	% Delivering <0 and < 0.5 kWh	% Delivering <0 and < 1.0 kWh	% Delivering <0 and >13.0 kWh
0.167	10	542	39	477	496	-	7%	88%	92%	
0.25	30	2,980	192	2,499	2,715	-	6%	84%	91%	
0.5	60	7,373	489	4,937	6,166	-	7%	67%	84%	
1	120	16,838	1,039	7,292	11,699	-	6%	43%	69%	
2	240	25,959	1,529	9,532	15,045	35	6%	37%	58%	0%
4	480	30,310	1,529	9,532	15,742	119	5%	31%	52%	0%
8	960	32,315	1,608	9,678	15,999	276	5%	30%	50%	1%
Over 8	>960	34,773	1,712	9,805	16,193	1,115	5%	28%	47%	3%