

Exhibit DPS-AM-5

#	Metric	Granularity	Type	Source	Notes
<i>GMP-proposed ZOI metrics to report in MYRP annual reporting</i>					
1	Total Customer CEMI (Customers Experiencing Multiple Interruptions) numbers by district (0 to max)	Systemwide	Performance	GMP, Exhibit GMP-MB-17	
2	GMP System Miles Undergrounded in FY	Systemwide	Attribute	GMP, Exhibit GMP-MB-17	
3	GMP System Miles Stormhardened in FY	Systemwide	Attribute	GMP, Exhibit GMP-MB-17	
4	Number of storage systems and total kW installed under ZOI	Systemwide	Attribute	GMP, Exhibit GMP-MB-17	
5	Battery type/size installed under ZOI, by manufacturer	Systemwide	Attribute	GMP, Exhibit GMP-MB-17	
6	Number of monthly peaks during which discharge successfully occurred during the RNS peak and the total capacity available during discharge (included with ESS systems in Metric 40)	Systemwide	Performance	GMP, Exhibit GMP-MB-17	
7	Whether the batteries were successfully discharged during the ISO New England annual forward capacity peak and the total capacity available during that discharge (included with ESS systems in Metric 41)	Systemwide	Performance	GMP, Exhibit GMP-MB-17	
8	Financial savings from peak shaving actually achieved (included with ESS systems in Metric 42)	Systemwide	Performance	GMP, Exhibit GMP-MB-17	
9	EAP Customers participating in ZOI Storage	Systemwide	Attribute	GMP, Exhibit GMP-MB-17	
10	Critical Medical Customers participating in ZOI Storage	Systemwide	Attribute	GMP, Exhibit GMP-MB-17	
11	SAIFI/CAIDI for Storage Customers by circuit (see ZOI by circuit tab)	Unclear, recommend	Performance	GMP, Exhibit GMP-MB-17	

		systemwide and by ZOI circuit			
12	% existing miles storm hardened	By ZOI circuit	Attribute	GMP, Exhibit GMP- MB-17	
13	% additional (or total) storm hardened	By ZOI circuit	Attribute	GMP, Exhibit GMP- MB-17	
14	% existing miles undergrounded	By ZOI circuit	Attribute	GMP, Exhibit GMP- MB-17	
15	% additional undergrounded	By ZOI circuit	Attribute	GMP, Exhibit GMP- MB-17	
16	% Zone 4 customer storage installed	By ZOI circuit	Attribute	GMP, Exhibit GMP- MB-17	
17	SAIFI	By ZOI circuit	Performance	GMP, Exhibit GMP- MB-17	
18	CAIDI	By ZOI circuit	Performance	GMP, Exhibit GMP- MB-17	
19	SAIFI/CAIDI average for storage customers per circuit	By ZOI circuit	Performance	GMP, Exhibit GMP- MB-17	
20	Circuit breaker lockouts per year	By ZOI circuit	Performance	GMP, Exhibit GMP- MB-17	
<i>PSD-proposed metrics to report in MYRP or SQRP; metrics in bold have suggested performance targets</i>					
21	SAIDI for rural feeders	Rural circuits	Performance	PSD, Mara PFT, p. 6	33% improvement target
22	SAIFI for rural feeders	Rural circuits	Performance	PSD, Mara PFT, p. 6	33% improvement target
23	CELID (customers experiencing long interruption durations - 12 hours or more in the year)	Systemwide	Performance	PSD, Jordan Surrebuttal, p. 6	
24	Outages by Environmental Justice Focus Population and Municipality	Systemwide	Performance	PSD, McIlvennie PFT, p. 18	
25	ZOI Investment by Environmental Justice Focus Population and Municipality	Systemwide	Attribute	PSD, McIlvennie PFT, p. 18	

26	Customer Experience of Outages	Systemwide	Attribute	PSD, McIlvennie PFT, p. 18	
27	Storm costs, rolling 5-yr average	By ZOI circuit	Performance	PSD, Mara PFT, p. 6	<\$13M by 2030
28	Battery failure to start index	By ZOI circuit	Performance	PSD, Mara Surrebuttal, p. 4	<=1% (rev. from <=5% in PFT)
29	Forced Outages per Hundred Miles per Year ("FOHMY")	By ZOI circuit	Performance	PSD, Mara PFT, p. 6	<=3.0 (GMP proposed #22 as alternative; PSD maintains original recommendation)
30	SAIFI with major storms	By ZOI circuit	Performance	PSD, Jordan Surrebuttal, p. 6	
31	CAIDI with major storms	By ZOI circuit	Performance	PSD, Jordan Surrebuttal, p. 6	
32	Time to restore service	By ZOI circuit	Performance	PSD, Margolis PFT, p. 15	
33	Critical facilities	By ZOI circuit	Attribute	PSD, Margolis PFT, p. 16	
34	Total customer minutes interrupted	By ZOI circuit	Performance	PSD, Margolis PFT, p. 16	
35	Percent of critical facility outages	By ZOI circuit	Performance	PSD, Margolis PFT, p. 16	
36	Time to restore 90% of customers	By ZOI circuit	Performance	PSD, Margolis PFT, p. 16	
37	Number of customer outages exceeding 120 hours (<i>also</i> 24, 48, and 96 hours)	By ZOI circuit	Performance	PSD, Margolis PFT, p. 16	